



Copies E-mailed to: 24/10/06
P. Badenhorst
L. Botha
N. Perring
G. Pieterse
E. Hill.



Verwysing
Reference 19/3/1/R
Isalathiso

Departement van Gesondheid
Department of Health
iSebe lezeMoilo

Navrae
Enquiries MP Abrahams
Imibuzo

Date:
Datum: 18 October 2006
Umhla:

Messrs. Chris Mulder & Associates Incorporated
P.O. Box 2498
KNYSNA
6570

Attention: Dr. Chris Mulder

GEORGE REX DEVELOPMENT: KNYNSNA

Receipt of your letter dated 10th October 2006 concerning the above mentioned is hereby acknowledge with thanks.

This office's evenly numbered letter dated 11th May 2006 also concerning the above mentioned refers, is no longer applicable and replaced by this letter.

The discussions held on 4th October 2006 between yourself, Messrs. J. Pieterse and R. Parry of Knysna Municipality, Mr. J. McCarthy of Eden District Municipality and Mr. M. Abrahams of Provincial Health also refers.

The officers of Knysna Municipality stated during these discussions that the wastewater treatment works would be suitable upgraded within the near future and that the Municipality is also committed to the maintenance and nuisance free operation of the WWTW.

In light of the above mentioned, this office supports the development of George Rex Place subjected to the following conditions:

- Knysna Municipality must have the capacity to supply all potable water to the development.
- All sewage is to be connected to the Knysna Municipal sewage system.

- The Municipal WWTW must be suitable upgraded by Knysna Municipality.
- The Knysna Municipal WWTW must in the meantime be operated in a nuisance free manner.
- The development of George Rex Place must coincide with and not before the upgrading of the Knysna Municipal WWTW.
- The Knysna Municipality must have an operational plan in place to combat any health nuisance, health hazard or pollution of the environment that might occur at the WWTW.
- A suitable screen must be put in place to minimize the effect of wind blown spray from the aerators.
- The George Rex Place development must also be suitable screened from the Municipal WWTW.
- The present driving range should be maintained as such to further act as a buffer zone between the development and the WWTW.
- All refuse must be incorporated into the Knysna Municipal solid waste removal and disposal system.

Yours faithfully



REGIONAL DIRECTOR: SOUTH CAPE/KAROO REGION
george rex place 2