

## REPORT ON ENGINEERING SERVICES FOR FEATHERBED NATURE RESERVE

### PORTION 59 OF 216 UITZICHT, BRENTON, KNYSNA

10<sup>th</sup> APRIL 2026

#### **CONTRACT:**

Name: FEATHERBED NATURE RESERVE  
Erf number: PTN 59 OF 216  
Our reference: 16/20

#### **CLIENT DETAILS:**

TMBArchitects Pty Ltd  
Post NetSuite 330  
Private Bag X31  
Knysna, 6570

Contact person: Tracey Mills Brink  
E-mail: [tracey@tracymillsbrink.com](mailto:tracey@tracymillsbrink.com)  
Tel: 076 922 6775

#### **DOCUMENT HISTORY:**

| Revision | Date:           | Comments |
|----------|-----------------|----------|
| 0        | 18 October 2024 |          |
| 1        | 10 April 2026   |          |
|          |                 |          |

# **REPORT ON ENGINEERING SERVICES FOR FEATHERBED NATURE RESERVE PORTION 59 OF 216 UITZICHT, BRENTON, KNYSNA**

## **CONTENTS**

|   |   |
|---|---|
| 1. Introduction   | 1 |
| 2. Access   | 2 |
| 3. Access Roads & Stormwater                              | 2 |
| 4. Facilities Creating a Demand on Services               | 3 |
| 4.1 Existing Main House & Proposed Entertainment Facility | 3 |
| 4.2 Existing Restaurants                                  | 3 |
| 4.3 Tours   | 3 |
| 4.4 Proposed Garages, Staff Toilets & Facilities          | 3 |
| 4.5 Proposed Conference Facility                          | 3 |
| 4.6 Proposed Manager's House                              | 3 |
| 4.7 Existing Staff Cottage                                | 3 |
| 5. Potable Water  | 4 |
| 5.1 Water Demand for Amenities in the Reserve             | 4 |
| 5.2 Water Demand for Fire Fighting                        | 4 |
| 5.3 Water Storage   | 4 |
| 5.4 Main Water Supply                                     | 5 |
| 5.4.1 Borehole #1   | 5 |
| 5.4.2 Borehole #2   | 5 |
| 5.5 Supplementary Water Supply                            | 5 |
| 5.6 Water Reticulation                                    | 6 |
| 6. Sewage Treatment & Disposal                            | 6 |
| 6.1 Sewage Generated                                      | 6 |
| 6.2 Existing Sewer Reticulation                           | 6 |
| 6.3 Existing Sewage Treatment & Disposal                  | 6 |
| 6.4 Proposed Sewage Treatment Process and Plant           | 6 |
| 6.4.1 Existing Septic Tank                                | 6 |
| 6.4.2 Proposed Septic Tank                                | 7 |
| 6.4.3 Proposed Sewage Treatment Plant                     | 7 |
| 7. Refuse Removal   | 7 |

**ANNEXURS**

- A. Site development plan
- B. Site development plan marked up with services
- C. Borehole # 1 pumping test report
- D. Borehole # 2 pumping test report
- E. Borehole # 1 water quality test report (STILL WAITING FOR RESULTS)
- F. Borehole # 2 water quality test report (STILL WAITING FOR RESULTS)
- G. Sewage treatment plant report & proposal

## 1. **Introduction**

The Featherbed Nature Reserve on portion 59 of Uitzicht 216, currently operates as a facility for tourists offering a choice of 4 restaurants, lagoon cruises on board one of their boats, bus and walking tours in the Nature Reserve.

The owner intends to construct some new facilities including a new garage building, a managers' house, a conference centre with tourist accommodation and an entertainment facility for the owner and his guests.

This report on Services is required in terms of the environmental approval process.

The Reserve is situated on the Western Head at the entrance to the Knysna Estuary.

The Nature Reserve has a large jetty to facilitate loading and offloading of tourists and staff from their sailboat and ferries.

## 2. Access

Most guests access the Reserve on the Featherbed ferries or in private boats embarking and disembarking at the large jetty East of the Reserve. Most of the staff are also brought in by boat.

## 3. Access Road & Stormwater

Road Access is via the Brenton on Lake Road and a brick paved access road providing access to Western Heads properties, bordering on the West bank of the estuary.

The roads in the Reserve are concrete or brick paved roads. Disposal of Stormwater relies on the highly permeable sandy soil allowing stormwater to soak-away. Grassed berms guide stormwater from the roads into specially constructed detention ponds where stormwater is allowed to soak away.

Great care has to be taken however to avoid concentrating stormwater, as the dune sand is highly erodible when water flows over it. The existing stormwater disposal system seems to work well as there are very few signs of erosion on the reserve. A dedicated stormwater management plan has been requested to form part of the documentation required for the environmental approval process.

#### **4. Facilities Creating a Demand on Services**

##### **4.1 Existing Main House & Proposed Entertainment Facility**

The main house has 7 bedrooms for owner and guests. The entertainment facility for the owner and guests will have a squash court, swimming pool, gym, spa, steam room, bar, showers and toilets. This building will be approximately 900m<sup>2</sup> in extent.

##### **4.2 Existing Restaurants**

There are four restaurants on the Reserve:

Food Forest – 150 seats

Milkwood – 130 seats

Top Deck – 100 seats

Beach Bar – 90 seats

##### **4.3 Tours**

The Reserve can host 5 tours a day with a maximum of 75 people per tour = 375 people per day on tours to the reserve.

##### **4.4 Proposed Garages, Staff Toilets & Facilities**

The garages for the storage and maintenance of vehicles, machinery and boats used on the reserve will also house staff toilets, changing rooms and canteen facilities. The buildings will be approximately 714m<sup>2</sup> in extent.

##### **4.5 Proposed Conference Facility**

A conference facility with bar, restaurant and tourist accommodation will be constructed on the property. The size of this building will be approximately 615m<sup>2</sup> in extent.

##### **4.6 Proposed Managers House**

A Manager's House approximately 285m<sup>2</sup> in extent will be constructed close to the conference facility. The house will accommodate the Manager and his or her family.

##### **4.7 Existing Staff Cottage**

There is a small existing staff cottage constructed to the North of the sewage treatment works.

## 5. Potable Water

### 5.1 Water Demand for the Amenities in the Reserve

The Water demand is estimated using the Guideline for Human Settlement Planning and Design “The Red Book”.

The Annual Average Daily Water Demand (AADD) is:

|  |                              |
|--|------------------------------|
| Existing Main House  | 2 000 litres per day         |
| Proposed Entertainment facility                              | 2 000 litres per day         |
| Proposed Garages, Staff Toilets & Car Wash                   | 1 000 litres per day         |
| Proposed Conference Centre & Accommodation                   | 2 500 litres per day         |
| Proposed Managers House                                      | 700 litres per day           |
| Existing Staff Cottage                                       | 600 litres per day           |
| Existing Restaurants 470 seats at 69 – 90 litres per day     | 37 600 litres per day        |
| Tours 375 people per day at say 50 litres per person per day | <u>18 600 litres per day</u> |

**TOTAL: 65 500 litres per day**

### 5.2 Water Demand for Fire Fighting

This development does not, in my opinion, fall into one of the fire risk categories contemplated in the red book

Intuitively, I would advise some sort of firefighting capability provided by constructing two or three fire hydrants on the water reticulation in strategic positions. Fire-fighting could take place using lay flat hoses fed from the hydrants. Firefighting trucks could also fill up their tanks at these hydrants. The buildings on the property will be fitted with fire hose reels and fire extinguishers.

The lowest fire category in the Red book, requiring hydrants and water storage for firefighting purposes would be Low Risk Group 3, which calls for a fire flow of 350 litres per minute and water storage for one hour of fire flow. I would recommend that the development aims at this capability.

### 5.3 Water Storage

In terms of the Red Book Guidelines, water storage must be provided to satisfy:

- a) 2 Days of AADD = 2 x 65 000 litres = 130 000 litres  
 b) 1 Hour of fire flow = 60 min x 350 litres / min = 21 000 litres

**Total reservoir storage = 151 000 litres**

The developer needs to provide 151 000 litres of water storage on site, preferably roofed.

The development currently has six 10 000 litres of water storage = 60 000 litres of water storage.

## **5.4 Main Water Supply**

There are two on-site boreholes situated close to the sewage treatment works and generator.

### **5.4.1 Borehole #1**

Borehole #1 is situated on the level platform about 10m North of the existing generator. This borehole is 73m deep. The recommended max abstraction rate is 1.2 l/sec or 4320 l/hour.

Attached is the borehole test report for this borehole and a water quality test report for the water from the borehole.

### **5.4.2 Borehole #2**

Borehole #2 is situated at the intersection of the road to the top of the reserve and the road to the sewage treatment plant. This borehole is 82 m deep. The recommended max abstraction rate of 1.0 l/sec or 3600 l/hour

Attached is the borehole test report for this borehole and a water quality test report for the water from this borehole.

The two boreholes will provide the AADD for the development of 65kilolitres per day in 8.2 hours of pumping at a combined rate of 7920 litres/hour litres per hour.

**The water quality has been tested. Test results are attached. These are satisfactory. (Reports not yet received)**

Water from the boreholes will be filtered & sterilized with chlorine or UV before being pumped into the reservoir.

## **5.5 Supplementary Water Supply**

Rainwater from the roofs of the four proposed buildings will be harvested as part of the Stormwater Management Plan. The roof areas are:

|                        |                                 |
|------------------------|---------------------------------|
| Entertainment facility | approximately 902m <sup>2</sup> |
| Garages, Staff Toilets | approximately 714m <sup>2</sup> |
| Conference Centre      | approximately 615m <sup>2</sup> |
| Managers House         | approximately 285m <sup>2</sup> |

Rainwater from the roofs of the entertainment centre and the garages and staff ablutions buildings will be collected in ten 10 000litre water tanks to be positioned alongside the garage building. Th harvested water will be pumped at a rate of 20 000 litres per hour through sand filters to a proposed 320 kilolitre water reservoir to be constructed close to the sewage treatment plant. Further, the rainwater from the roofs of the conference centre and Manager's house will be collected in four 10 000 litre tanks positioned adjacent to the Manger's house. This water will also be pumped at a rate of 20 000 litres per hour through sand filters to the 320 kilolitre roof water reservoir.

Water from this reservoir will be used when available, to ensure that the reservoir is empty when a new rainfall event starts.

## **5.6 Water Reticulation**

Water is currently fed through a gravity reticulation system to the various buildings in the Reserve. The elevation of the water storage tanks provides adequate pressure in the reticulation.

The water reticulation should be expanded & improved as necessary to feed the two or three fire hydrants to be erected on the property, as well as the proposed new buildings.

## **6. Sewage Treatment & Disposal**

### **6.1 Sewage Generated**

In a development of this nature 95% of the water consumed ends up in the sewers. Sewage generated: 95% of 64 400 litres = 61 750 litres per day.

### **6.2 Existing Sewer Reticulation**

Sewage is collected in a reticulation of gravity sewers which collect sewage from all the buildings in the reserve (apart from the staff cottage which has its own septic tank and soak away system) and feeds into a 40 000litre septic tank situated adjacent to the restaurant building. Liquid effluent from the septic tank is pumped to the existing sewage treatment plant situated close to the generator and boreholes where it is treated.

### **6.3 Existing Sewage Treatment & Disposal**

This septic tank(s) performs the anaerobic digestion function of the sewage treatment process. The outflow from the septic tank(s) is then pumped from a sump to the second part of the sewage treatment package plant which is situated higher up on the Reserve. This second part should perform further anaerobic digestion of the sewage before it enters the aerobic digestion section and clarifier. The clarified effluent should then be sterilized using UV light, ozone or chlorine before being pumped to a soak away area.

Inspection of this second part of the plant with sewage treatment experts revealed that the plant is not functioning properly and cannot function properly without major modifications. There is also no sterilization process available.

### **6.4 Proposed Sewage Treatment Process & Plant**

#### **6.4.1 Existing Septic Tank**

Gravity sewers will convey sewage from the restaurants, Main House and Proposed Entertainment Facility to the existing 40 000-litre septic tank from where liquid effluent will be pumped to the sewage treatment plant.

#### **6.4.2 Proposed Septic Tank**

Gravity sewers will be laid to convey sewage from the proposed garages and staff ablutions, the conference centres and the Manager's house into an 8 500-litre septic tank to be constructed adjacent to the Manager's House. Liquid effluent from this septic tank will be pumped to the sewage treatment plant.

#### **6.4.3 Proposed Sewage Treatment Plant**

The existing sewage treatment plant (improved & extended) or a new sewage treatment plant, capable of treating 62 000-litres of sewage a day will be constructed on the site of the existing plant. In this new or improved / extended plant, sewage will be broken down in a combination of anaerobic and aerobic digestion processes in which specialized bacteria will break down and consume the solids.

A clarifier will then separate out sludge which will be returned to the aerobic digester. Treated effluent from the clarifier will be sterilized using chlorine, ozone or UV light and will then be pumped to a soak-away tank from which it will soak away into the permeable in situ sand.

Periodic testing of the treated effluent must be carried out to ensure it meets minimum standards.

### **7. Refuse Removal**

Refuse is collected in the Reserve and sorted into:

- a) Refuse for the dump
- b) Recycling material
- c) Compostable material
- d) Food waste suitable for use by pig farmers.

Refuse for the dump is transported to the Municipal solid waste transfer station from where it is carted to Mossel Bay where it is disposed of in landfill.

Recyclable material is carted to the recycling facility in the industrial area for recycling.


Compostable material is composted in the Reserve and the compost used for landscape gardening.

Food waste is carted to pig farms where it is consumed by pigs.



T N  
SCALE 1:500

- LEGEND:**
- Existing Borehole
  - Proposed Sewer Line
  - Proposed Sewer Pump Line
  - Septic Tank
  - Proposed Stormwater Line
  - Proposed Stormwater Pump Line
  - Rain Water Tanks
  - Proposed Soak away.



|  |                         |                            |          |            |
|--|-------------------------|----------------------------|----------|------------|
| CLIENT   |                         | FEATHERBED NATURE RESERVE. |          |            |
| PROJECT  |                         | FEATHERBED NATURE RESERVE  |          |            |
| TITLE  |                         | PROPOSED CIVIL SERVICES    |          |            |
| SCALE  |                         | PAPER SIZE                 |          | DRAWING NO |
| NTS  |                         | A3                         |          | 16-20-001  |
| HOFMEYR & ASSOCIATES                                     |                         | DATE                       | DESIGNED | RH         |
| 1 JONKER STREET<br>KNYSNA INDUSTRIAL<br>KNYSNA, 6570     |                         | APRIL 2026                 | DRAWN    | JV         |
| tel 044-382 0936<br>hofmeyr@hofmeyr<br>assoociates.co.za |                         | CHECKED                    | RH       | 0          |
| 0  | PROPOSED CIVIL SERVICES | 06/04/2026                 | RH       |            |
| NO   | DESCRIPTION             | DATE                       | SIGNED   | REVISIONS  |
|  | REVISIONS DETAILS       |                            |          |            |

# GEOHYDROLOGICAL INVESTIGATION REPORT

## *BOREHOLE CAPACITY AND WATER QUALITY TESTING*

*For*

### *FEATHERBED NATURE RESERVE BOREHOLE 01.*



**08<sup>th</sup> of April 2026**

**Report prepared by**

Baron Vutoyi (Pri. Sci.Nat. 120060)

044 050 1151

**Report reviewed by**

*Renaldo Taute*

+27 60 640 3546

[sales3@arenagroup.co.za](mailto:sales3@arenagroup.co.za)

**Table of Contents**

|   |  |
|---|--|
| ACCEPTANCE LETTER.....  | 3  |
| PROFILE OF THE CONSULTANT .....   | 4  |
| 1. INTRODUCTION .....   | 5  |
| 1.1. Background .....   | 5  |
| 1.3. Geology of Featherbed Nature Reserve .....                         | 6  |
| 1.4. Hydrogeology .....   | 6  |
| 2. AQUIFER SUSTAINABILITY TESTING FOR BOREHOLES.....                    | 7  |
| 2.1. Step Tests .....   | 7  |
| 2.2. Constant Discharge Test .....                                      | 7  |
| 2.3. Recovery Readings .....  | 7  |
| 3. AQUIFER TEST DATA RESULTS FOR FEATHERBED NATURE RESERVE B/H 01. .... | 8  |
| 3.1. Step Testing Results .....   | 8  |
| 3.2. Constant discharge Test results .....                              | 9  |
| 3.3. Recovery testing results .....                                     | 10   |
| 4. WATER QUALITY ANALYSIS.....  | 12   |
| 4.1. Sampling procedure .....   | 12   |
| 4.2. Water quality.....   | 12   |
| 5. CONCLUSIONS AND RECOMMENDATIONS .....                                | 13   |
| 5.1. RECOMMENDATIONS .....  | 13   |
| 5.2. CONCLUSIONS.....   | 13   |
| 6. REFERENCES.....  | 14   |
| APPENDIX A- BOREHOLE TEST RESULTS .....                                 | 15   |
| <b>FEATHERBED NATURE RESERVE BOREHOLE 01 TEST RESULTS.....</b>          | <b>15</b>  |
| <br>  |  |
| <b>Figure</b>   |  |
| Figure 01   | Google Earth Location of Featherbed Nature Reserve Borehole 01. 5                      |
| <br>  |  |
| <b>Graphs</b>   |  |
| Graph 1   | Graph of Step Drawdown Test of Featherbed Nature Reserve Borehole 01. 8                |
| Graph 2   | Graph of Constant Discharge test of Featherbed Nature Reserve Borehole 01. 9           |
| Graph 3   | Graph of Derivative Plots And T- And S – Values Vs Log – Time Borehole 01. 10          |
| Graph 4   | Graph of Recovery Test Vs Log – Time Of Featherbed Nature Reserve Borehole 01. 10      |
| <br>  |  |
| <b>Tables</b>   |  |
| Table 1   | Information of Featherbed Nature Reserve Borehole 01. 8                                |
| Table 2   | Drawdown Data - Step Test of Featherbed Nature Reserve Borehole 01. 8                  |
| Table 3   | Drawdown - Constant Discharge Test Featherbed Nature Reserve Borehole 01. 9            |
| Table 4   | Drawdown Data Recovery & Step Test Recovery of Featherbed Nature Reserve B/H 01. 10    |
| Table 5   | Water Quality Analysis for Human Consumption of Featherbed Nature Reserve B/H 01. 11   |
| Table 6   | Recommended Installation and Abstraction Rate for Featherbed Nature Reserve B/H 01. 12 |

## ACCEPTANCE LETTER

26<sup>th</sup> of March 2026  
Corner of Rand & Bank Street  
George Industrial  
Western Cape, 6536

**Attention: Sir / Madam**

**Ref: Geohydrological Report for Featherbed Nature Reserve Borehole 01.**

Arena Group is pleased to present our Geohydrological Investigation Report for Featherbed Nature Reserve Borehole 01. This report contains a summary of the results of Borehole Capacity Testing and Water Quality Testing fieldwork investigation which was conducted on the 26<sup>th</sup> of March 2026 till the 28<sup>th</sup> of March 2026 by Arena Group.

We trust that this report contains the information required and we thank you for the opportunity to assist you on this project. Copies of Geohydrological Investigation Report have been distributed as indicate in the table below:

| <i>Distribution List</i>         | <i>Date issued</i> | <i>Number of Copies</i>    |
|----------------------------------|--------------------|----------------------------|
| <i>Mr. B. Vutoyi</i>             | 09/04/2026         | 1 Electronic and Hard Copy |
| <i>Arena Group</i>               | 09/04/2026         | 1 Electronic and Hard Copy |
| <i>Featherbed Nature Reserve</i> | 09/04/2026         | 1 Electronic and Hard Copy |

If you have any questions regarding the contents of this report, please call our office.

Yours Sincerely,



Baron Vutoyi

Geo hydrologist /Hydro Geologist (Pri. Sci. Nat Registered 120060)

**Tel:** 044 050 1151.

**Cell:** +27 63 640 3546.

**Email:** sales3@arenagroup.co.za

---

## PROFILE OF THE CONSULTANT

### GEO-HYDROLOGICAL CONSULTANT'S EXPERIENCE

- **Company** : Arena Group
- **Geo-Hydrological Consultant** : Baron Vutoyi
- **Telephone Number** :044 050 1151 / 086 999 0823
- **E-mail address** :[sales3@arenagroup.co.za](mailto:sales3@arenagroup.co.za)

### QUALIFICATIONS

- B.Sc. (Honours) Environmental Sciences, NWU, 2014.
- B.Sc. (Honours) Information Technology, NWU, 2011.
- B.Sc. Statistics & Geology, UZ, 2004,

### PROFESSIONAL REGISTRATION BOARDS

- SACNASP, Pri. Sci. Nat. 120060
- SAQA, NQF 7

### KEY EXPERIENCES:

- Project management, coordinating & supervising the work of professional and technical staff, designing, implementation, monitoring, communicating with the client & subcontractors through regular meetings, emails etc. and composing of concise technical reports for projects;
- Undertake specialist input into Basic Assessments, Environmental Impact Assessments, Water Use Licenses, Planning geophysical surveys and interpretation of data (obtained from Magnetometers, Electromagnetics, Resistivity etc.), Design and construction of production boreholes and monitoring wells in varied geological environments, Planning and execution of drilling, geological logging/mapping, camera inspection, hydraulic tests and interpretation of data, Data analysis and interpretation of hydro geochemical data, Understanding and experienced with conceptual hydrogeological models, numerical flow models;
- Ability to work in a multi-disciplinary team and an environment which promotes a high safety culture.

## 1. INTRODUCTION

### 1.1. Background

Following the appointment of Arena Group by Featherbed Nature Reserve to conduct a borehole capacity and water quality testing to understand the aquifer yield and determine the correct pump to be installed. Four stages were conducted comprising of Step Testing, Constant Discharge Testing, Recovery Testing and Water Quality Testing to understand the sustainability / capacity of the borehole and hence make best possible recommendations for the borehole installation and usability. This study relied on expert knowledge and literature sources to assess and evaluate the current water resources and determine their productive capacity.

### 1.2. Location of the Borehole

A Google map showing the Featherbed Nature Reserve Borehole 01 location is presented below.



**Figure 01: Google Earth Location of Featherbed Nature Reserve Borehole 01.**

---

### 1.3. Geology of Featherbed Nature Reserve

The area and surrounding area of Featherbed Nature Reserve is underlain by rock formations of the Peninsula Formation, which form the base of the Table Mountain Group and the base of the Cape Supergroup. The Peninsula Formation is classified as *Ordovician* in age ( $\pm 480$  Ma). The Peninsula Formation (although not visible within this area specifically) was deposited on top of tilted and folded rocks of the Malmsbury Group and granites of the Cape Granite Suite and that it comprises at least half of the Table Mountain Group and its thickness varies from 1800 – 2150 m. It is composed of a monotonous succession of medium to coarse-grained, thickly bedded, greenish grey sandstone which weathers whitish.

The deposition was mainly from the north into the fairly stable basin. With time and as more and more layers of rock formations were deposited on top, and due to pressure and heat, these beach sands were metamorphosed into sandstone and eventually into quartzites.

### 1.4. Hydrogeology

The regional aquifer directly underlying the Featherbed Nature Reserve Borehole 01 is classified by the Department of Water Affairs and Forestry (DWAFF, 2002) as a fractured aquifer with an average yield potential of 0.1 – 0.5 L/s. A fractured aquifer describes an aquifer where groundwater only occurs in narrow fractures within the bedrock.

Based on the DWAFF (2002) mapping of the regional groundwater quality, the electrical conductivity (EC), the majority of the area surrounding the Featherbed Nature Reserve Borehole 01 is approximately to be in the range of 0 -70 mS/m. This is considered to be “moderate to poor” quality for water with respect to drinking water standards. Both these classifications are based on regional datasets, and therefore only provide an indication of conditions to be expected.

---

## 2. AQUIFER SUSTAINABILITY TESTING FOR BOREHOLES

Featherbed Nature Reserve Borehole 01 was aquifer tested by Arena Group. The test data has been analysed and is discussed below. In short, aquifer testing entails the following:

### 2.1. Step Tests

The borehole is pumped at varying abstraction rates for periods of 60 minutes each and water levels are measured in the borehole at pre-determined intervals. A recorded sheet is attached in the appendix. The test effectively stresses the hole and gives an indication of its capable yield. The abstraction rate for the longer duration aquifer sustainability test is determined from the step test and its resultant data; hence a blow yield of the borehole has to be identified.

### 2.2. Constant Discharge Test

The Constant Discharge Test is usually carried for a period of approximately 24-hours and involves measuring the water levels in the borehole while pumping the water out and thus creating “drawdown” within the borehole. Drawdown is the difference between the measured Water Level at any time during the test and the position at which the Water Level would have been Static Water Level (SWL) if abstraction had not taken place. The main aim of the test is to lower the Water Level in the borehole to approximately 65% of the Available Drawdown and maintain the Water Level at this depth. The Constant Discharge Test is performed to assess the productivity of the aquifer according to its response to the abstraction of water. The response is analysed to provide information regarding the hydraulic properties of the groundwater and arrive at an optimum yield for the medium to long-term utilization of the borehole.

### 2.3. Recovery Readings

The rate at which the borehole recovers (WL rises) is also measured and recorded once the pump is switched off. This data is useful in determine the storage available to the borehole and the position of the main water strike(s).

### 3. AQUIFER TEST RESULTS FOR FEATHERBED NATURE RESERVE B/H 01.

The details of the aquifer test set-ups of Featherbed Nature Reserve Borehole 01 are presented below;

#### 3.1. Step Testing Results


**Table 1: Information of Featherbed Nature Reserve Borehole 01.**

| Borehole Name             |               | Coordinates   |               | Borehole Information |  |
|---------------------------|---------------|---------------|---------------|----------------------|--|
| Site Name                 | Latitude      | Longitude     | B/H Depth (m) | SWL (m)              |  |
| Featherbed Nature Reserve | 34° 4'26.56"S | 23° 2'55.14"E | 82.00         | 49.00                |  |

**Table 2: Drawdown Data - Step Test of Featherbed Nature Reserve Borehole 01.**

| Steps   | L/s  | Depth of Pump (m) | Dynamic Water Level (m) | Drawdown (m) | Percentage of Drawdown (m) |
|---------|------|-------------------|-------------------------|--------------|----------------------------|
| Step 01 | 0,50 | 80,00             | 52,60                   | 27,40        | 34,25                      |
| Step 02 | 1,00 | 80,00             | 57,90                   | 22,10        | 27,63                      |
| Step 03 | 1,50 | 80,00             | 65,20                   | 14,80        | 18,50                      |
| Step 04 | 3,00 | 80,00             | 77,00                   | 3,00         | 3,75                       |

**Graph of Step Test Charge of the Borehole Vs Log – Time.**



**Graph 1: Graph of Step Drawdown Test of Featherbed Nature Reserve Borehole 01.**

Analysis of the step-drawdown data indicated that the constant discharge test could be performed at a constant rate of 1.00 L/s for a period of twenty-four hours without failing.

### 3.2. Constant discharge Test results


**Table 3: Drawdown - Constant Discharge Test Borehole 01.**

| Constant Discharge | Duration Hours | Depth of Pump (m) | Static Water level (m) | Available Drawdown (m) | Dynamic Water Level (m) | Available Drawdown (m) | %age of Available Drawdown |
|--------------------|----------------|-------------------|------------------------|------------------------|-------------------------|------------------------|----------------------------|
| 1.00 L/s           | 24,00          | 80.00             | 49.00                  | 31.00                  | 57.40                   | 22.60                  | 95.48                      |

ALL calculation done above the static water level used is 49.00 mbgl and available drawdown is 31.00 mbgl after pump installation.

#### Graph of Constant Discharge Test of the Borehole Vs Log – Time.


Graph 2 below presents a graphical summary of the Constant Discharge Test and possible depth of water strikes that exists in the borehole 01.



**Graph 2: Graph of Constant Discharge test of Featherbed Nature Reserve Borehole 01.**

The CDT was carried out for a period of a 24-hours at 1.00 L/s on average and achieved a maximum drawdown of 29.60 meters remained available which is 95.48 % of the available drawdown was available after constant discharge testing.

**Derivative Plots And T- And S – Values Vs Log – Time**



**Graph 3: Graph of Derivative Plots And T- And S – Values Vs Log – Time**

The graph above shows possible water strikes at 56.50 mbgl , 57.20 mbgl, and 51.60 mbgl.

**3.3. Recovery testing results**


The recovery of the water level was monitored for both Step Test and CDT and is presented in the table below:

**Table 4: Drawdown Data Recovery and Step Test Recovery of Featherbed Nature Reserve Borehole 01.**

| Test          | Duration Minutes | Available Drawdown (m) | Static Water Level (m) | Dynamic Water Level (m) | Unrecovered | %age of recovered drawdown (m) |
|---------------|------------------|------------------------|------------------------|-------------------------|-------------|--------------------------------|
| Step Test     | 90,00            | 31,00                  | 49,00                  | 50,20                   | 1,20        | 96.45                          |
| Constant Test | 90,00            | 30,30                  | 49,70                  | 57,40                   | 1,00        | 99.26                          |

The step test water level in the borehole recovered to 99.45 % of the static water level in 90 minutes after pumping stopped and in the constant discharge test the water level in the borehole recovered to 99.26 % after the pump was switched off in 90 minutes. In all the tests more than 65% of extracted water. This is an indication that the borehole recovers fast and has a good fracture network.

**Graph of Recovery Test of the Borehole Vs Log – Time.**



**Graph 5: Graph of Recovery Test Vs Log – Time of Featherbed Nature Reserve Borehole 01.**

It was observed that the borehole recovers very fast. Within an hour the borehole had recovered more than 65 % of the drawdown water pumped during constant discharge.

## 4. WATER QUALITY ANALYSIS

### 4.1. Sampling procedure

Groundwater samples are ideally collected and sent to a SANAS Accredited Laboratory (Western Cape Laboratory) for potability analysis. The sample are taken according to the DWAF standards, at the end of the Constant Discharge Test in order to be representative of the water of a wider zone around the borehole.

### 4.2. Water quality

Water quality of domestic water, utilized for human consumption and food preparation, must be safe to use if the consumers' health is to be protected. For this reason, the "Quality of Domestic Water Supplies" (Second edition, 1998)" was set forward by the Department of Water Affairs and Forestry, Department of Health and the Water Research Commission in 1998. This document facilitates the evaluation of water on the basis of five water quality classes:

**Table 5: Water Quality Analysis for Human Consumption,**

| CLASS   | pH            | TDS        | EC        | Total Hardness | Ca           | Mg         | Cl         | NO2           | Na         | K         | F           |
|---------|---------------|------------|-----------|----------------|--------------|------------|------------|---------------|------------|-----------|-------------|
| Class 0 | 5.00 - 9.50   | <450       | <70       | 0 -200         | 0.00 - 30.00 | <100       | <100       | <6            | <100       | <25       | <0.7        |
| Class 1 | 4.50 - 5.00   | 450 - 1000 | 70 - 150  | 200 - 300      | 30 - 150     | 100 - 200  | 100 - 200  | 6.00 - 10     | 100 - 200  | 25 - 50   | 0.70 - 1.00 |
| Class 2 | 4.00 - 4.50   | 1000 -2400 | 150 -370  | 300 - 400      | 150 - 300    | 200 - 400  | 200 - 600  | 10.00 - 20.00 | 200 - 400  | 50 - 100  | 1.00 - 1.50 |
| Class 3 | 3.00 - 4.00   | 2400-3400  | 370 - 520 | >400           | >300         | 400 - 1200 | 600 - 1200 | 20 - 40.00    | 400 - 1000 | 100 - 500 | 1.50 - 3.50 |
| Class 4 | <3.00 ->11.00 | >3400      | >520      |                |              | >1200      | >1200      | >40.00        | >1000      | >500      | >3.50       |

**Class 0 :** ideal water quality, suitable for lifetime.

**Class 1 :** Good water quality, suitable for use, rare instances of negative effects

**Class 2 :** Marginal water quality-conditionally acceptable, Negative effects may occur in some cases to sensitive groups .

**Class 3 :** Poor water quality, Unsuitable for use without treatment. Chronic effects may occur.

**Class 4 :** Dangerous water quality, totally unsuitable ,for use. Acute effects may occur.

However, there was no water sample collected and sent to the Water Laboratory for Water Quality Testing and analysis of the result. It is advisable that water quality is done depending on the water use.

This data should be analysed by a qualified Hydrogeologist to ensure long term sustainable use the of the borehole. The legal compliance regarding the use of the groundwater also needs to be addressed with the Department of Water and Sanitation.

## 5. CONCLUSIONS AND RECOMMENDATIONS

### 5.1. RECOMMENDATIONS

Based on the aquifer test data, assessing of the pumping curves, location of the borehole relative to other boreholes and the recovery data, the following abstraction and installation recommendations has been made:

| Table 6: Recommended Installation and Abstraction Rate for Featherbed Nature Reserve Borehole 01. |               |
|---|---------------|
| Borehole Depth  | 82,00 mbgl    |
| Borehole Pump Depth   | 80,00 L/s     |
| Rest Water Level  | 49,7 mbgl     |
| Borehole Pumping Rate   | 1,00 L/s      |
| Borehole Pumping Duration   | 1 440 minutes |
| Borehole Recovery Duration  | 90 minutes    |
| Transducer  | Yes           |
| Litres per Second   | 1,00 L/s      |
| Litres per Minutes  | 60 L/Minute   |
| Litres per Hour   | 3 600 L/Hour  |
| Litres in 24 Hours  | 86 400 L/day  |
| Critical Water Level  | 49,700 mbgl   |
| Dynamic Water Level   | 57,40 mbgl    |

### 5.2. CONCLUSIONS

As of January 2018 the Department of Water and Sanitation released a Government Gazette stating that: "All water use sector groups and individuals taking water from any water resource (surface or groundwater) regardless of the authorization type, in the Berg, Olifants and Breede Gouritz Water Management Area, shall install electronic water recording, monitoring or measuring devices to enable monitoring of abstractions, storage and use of water by existing lawful users and establish links with any monitoring or management system as well as keep records of the water used." Therefore, to facilitate monitoring and informed management of a borehole, it is highly recommended that a borehole be equipped with the following monitoring infrastructure and equipment:

- Installation of a 32 mm (inner diameter, class 10) observation pipe from the pump depth to the surface, closed at the bottom and slotted for the bottom 5 – 10 m. This

allows for a 'window' of access down the borehole which enables manual water level monitoring and can house an electronic water level logger.

- Installation of an electronic water level logger (for automated water level monitoring)
- Installation of a sampling tap (to monitor water quality) if required.
- Installation of a flow volume meter (to monitor abstraction rates and volumes)

## 6. REFERENCES

- ACOCKS, J.P.H., (1988). Veld Types of South Africa. Memoirs of the Botanical Survey of South Africa no. 57, 146pp.
- Buttner, S.H., Reid, W.K. & Erasmus, R. (2016). Late Permian tectonics and associated fluid influx during the Cape Orogeny: evidence from fault-bound quartz veins in the Wittenberg Group (Cape Super group, South Africa). South African Journal of Geology, Volume 119.2 Page 379- 398.
- DWAF (2002). The hydrogeological map series of the republic of South Africa. Scale: 1:500 000.
- Department of Water Affairs and Forestry (1999). Minimum Standards and Guidelines for Groundwater Resource Development for the Community Water Supply and Sanitation Programme. (First Edition).
- HEM, J.D. (1970). Study and interpretation of the chemical characteristics of natural water. 2nd edition. U.S Geol. Survey. Water Supply Paper 1473, 363pp.
- Holmes, P, J, Marker, M. 2002: The Distribution and Environmental Implications of Cover sand Deposits in the Southern Cape, South Africa. South African Journal of Geology, 2002, 105, (135146).
- National water act (1998). The national water act, NO 36. Department of Water Affairs and Forestry. Pretoria.
- MIDGLEY, D.C., PITMAN, W.V., MIDDLETON, B.J. (1994). Surface water resources of South Africa 1990. WRC Report no 298/6.2/94, Vol. V1 Appendices (First edition).



[sales3@arenagroup.co.za](mailto:sales3@arenagroup.co.za)

---

**ARENA GROUP**

**Corner of Rand and Bank Street  
George Industrial, Western Cape, 6536  
+27 (086) 999 0823, +27 (044) 050 1151**

## **APPENDIX A- BOREHOLE TEST RESULTS**

### ***FEATHERBED NATURE RESERVE BOREHOLE 01 TEST RESULTS***

| FORM 5F  |            |       |          |          |                              |   |                                |                           |             |             |       |       |          |          |
|--|------------|-------|----------|----------|------------------------------|---|--------------------------------|---------------------------|-------------|-------------|-------|-------|----------|----------|
| BOREHOLE TEST RECORD SHEET- STEP TEST DISCHARGE & RECOVERY |            |       |          |          |                              |   |                                |                           |             |             |       |       |          |          |
| Alt Borehole   | None       |       |          |          |                              |  | Province                       | Western Cape              |             |             |       |       |          |          |
| Alt Borehole   | None       |       |          |          |                              |   | District                       | Krygsna Municipality      |             |             |       |       |          |          |
| Depth of Borehole  | None       |       |          |          |                              |   | Site Name                      | Featherbed Nature Reserve |             |             |       |       |          |          |
|  |            |       |          |          |                              | Date  | 26 <sup>th</sup> of March 2026 |                           |             |             |       |       |          |          |
| Borehole Depth   | 82.00 mbgl |       |          |          | Datum Level Above Casing (m) | 0.90  |                                | Pump Installed            | Submersible |             |       |       |          |          |
| Water Level  | 49.00 mbgl |       |          |          | Casing Height (magl)         | 0.00  |                                | Contractor                | Arena Group |             |       |       |          |          |
| Depth of Pump  | 80.00 mbgl |       |          |          | Diameter of the Pump (mm)    | 160.00  |                                | Pump Type                 | DW15M       |             |       |       |          |          |
| STEP TEST & RECOVERY                                       |            |       |          |          |                              |   |                                |                           |             |             |       |       |          |          |
| Discharge 1  |            |       |          |          | Discharge 2                  |   |                                |                           |             | Discharge 3 |       |       |          |          |
| Date:  | Time       |       | Recovery |          | Date:                        | Time  |                                | Recovery                  |             | Date:       | Time  |       | Recovery |          |
| Time   | D/D        | Yield | Time     | Recovery | Time                         | D/D   | Yield                          | Time                      | Recovery    | Time        | D/D   | Yield | Time     | Recovery |
| mins   | m          | L/s   | mins     | m        | mins                         | m   | L/s                            | mins                      | m           | mins        | m     | L/s   | mins     | m        |
| 1  | 52.50      | 0.50  | 1        |          | 1                            | 55.00   | 1.00                           | 1                         |             | 1           | 60.10 | 1.50  | 1        | 63.500   |
| 2  | 52.30      | 0.50  | 2        |          | 2                            | 55.40   | 1.00                           | 2                         |             | 2           | 61.20 | 1.50  | 2        | 6.00     |
| 3  | 52.10      | 0.50  | 3        |          | 3                            | 56.00   | 1.00                           | 3                         |             | 3           | 61.20 | 1.50  | 3        | 57.200   |
| 4  | 53.00      | 0.50  | 4        |          | 4                            | 56.50   | 1.00                           | 4                         |             | 4           | 62.00 | 1.50  | 4        | 55.800   |
| 5  | 53.00      | 0.50  | 5        |          | 5                            | 56.70   | 1.00                           | 5                         |             | 5           | 62.50 | 1.50  | 5        | 54.400   |
| 6  | 53.00      | 0.50  | 7        |          | 6                            | 56.80   | 1.00                           | 6                         |             | 6           | 63.20 | 1.50  | 6        | 52.700   |
| 7  | 53.00      | 0.50  | 9        |          | 7                            | 56.90   | 1.00                           | 7                         |             | 7           | 63.40 | 1.50  | 7        | 52.200   |
| 9  | 53.00      | 0.50  | 12       |          | 9                            | 57.00   | 1.00                           | 9                         |             | 9           | 63.50 | 1.50  | 9        | 51.500   |
| 12   | 52.70      | 0.50  | 15       |          | 12                           | 57.10   | 1.00                           | 12                        |             | 12          | 63.50 | 1.50  | 12       | 51.300   |
| 15   | 52.70      | 0.50  | 20       |          | 15                           | 57.70   | 1.00                           | 15                        |             | 15          | 63.70 | 1.50  | 15       | 50.800   |
| 20   | 52.70      | 0.50  | 25       |          | 20                           | 57.50   | 1.00                           | 20                        |             | 20          | 63.70 | 1.50  | 20       | 49.800   |
| 25   | 52.60      | 0.50  | 30       |          | 25                           | 57.60   | 1.00                           | 25                        |             | 25          | 63.70 | 1.50  | 25       | 49.800   |
| 30   | 52.60      | 0.50  |          |          | 30                           | 57.60   | 1.00                           | 30                        |             | 30          | 63.70 | 1.50  | 30       | 50.700   |
| 40   | 52.60      | 0.50  |          |          | 40                           | 57.80   | 1.00                           | 40                        |             | 40          | 65.20 | 1.50  | 40       | 50.400   |
| 50   | 52.60      | 0.50  |          |          | 50                           | 57.80   | 1.00                           | 50                        |             | 50          | 65.20 | 1.50  | 50       | 50.300   |
| 60   | 52.60      | 0.50  |          |          | 60                           | 57.90   | 1.00                           | 60                        |             | 60          | 69.9  | 1.50  | 60       | 50.200   |

Featherbed Nature Reserve Borehole 01\_ Borehole Capacity Testing Records\_R00

| FORM 5F   |      |            |       |          |          |   |     |                                |      |                |      |                           |          |        |  |
|---|------|------------|-------|----------|----------|---|-----|--------------------------------|------|----------------|------|---------------------------|----------|--------|--|
| BOREHOLE TEST RECORD SHEET - STEP TEST DISCHARGE & RECOVERY |      |            |       |          |          |   |     |                                |      |                |      |                           |          |        |  |
| Alt Borehole  |      | None       |       |          |          |  |     |                                |      | Province       |      | Western Cape              |          |        |  |
| Alt Borehole  |      | None       |       |          |          |   |     |                                |      | District       |      | Krygsna Municipality      |          |        |  |
| Depth of Borehole   |      | None       |       |          |          |   |     |                                |      | Site Name      |      | Featherbed Nature Reserve |          |        |  |
|   |      |            |       |          |          | Date  |     | 26 <sup>th</sup> of March 2026 |      |                |      |                           |          |        |  |
| Borehole Depth  |      | 82.00 mbgl |       |          |          | Datum Level Above Casing (m)  |     | 0.90                           |      | Pump Installed |      | Submersible               |          |        |  |
| Water Level   |      | 49.00 mbgl |       |          |          | Casing Height (magl)  |     | 0.00                           |      | Contractor     |      | Arena Group               |          |        |  |
| Depth of Pump   |      | 80.00 mbgl |       |          |          | Diameter of the Pump (mm)   |     | 160.00                         |      | Pump Type      |      | DW15M                     |          |        |  |
| Date:   |      | Time       |       | Recovery |          | Date:   |     | Time                           |      | Time           |      | 50.200                    |          |        |  |
| Time  |      | D/D        | Yield | Time     | Recovery | Time  | D/D | Yield                          | Time | Recovery       | Time | Recovery                  | Recovery |        |  |
| mins  | m    | L/s        | mins  | m        | mins     | m   | L/s | mins                           | m    | mins           | m    | L/s                       | mins     | m      |  |
| 1   | 74.2 | 3.00       | 1     |          | 1        |   |     | 1                              |      | 1              |      |                           | 70       | 50.200 |  |
| 2   | 74.9 | 3.00       | 2     |          | 2        |   |     | 2                              |      | 2              |      |                           | 80       | 50.200 |  |
| 3   | 77   | 3.00       | 3     |          | 3        |   |     | 3                              |      | 3              |      |                           | 90       | 50.200 |  |
| 4   |      |            | 4     |          | 4        |   |     | 4                              |      | 4              |      |                           |          |        |  |
| 5   |      |            | 5     |          | 5        |   |     | 5                              |      | 5              |      |                           |          |        |  |
| 6   |      |            | 6     |          | 6        |   |     | 6                              |      | 6              |      |                           |          |        |  |
| 7   |      |            | 7     |          | 7        |   |     | 7                              |      | 7              |      |                           |          |        |  |
| 9   |      |            | 9     |          | 9        |   |     | 9                              |      | 9              |      |                           |          |        |  |
| 12  |      |            | 12    |          | 12       |   |     | 12                             |      | 12             |      |                           |          |        |  |
| 15  |      |            | 15    |          | 15       |   |     | 15                             |      | 15             |      |                           |          |        |  |
| 20  |      |            | 20    |          | 20       |   |     | 20                             |      | 20             |      |                           |          |        |  |
| 25  |      |            | 25    |          | 25       |   |     | 25                             |      | 25             |      |                           |          |        |  |
| 30  |      |            | 30    |          | 30       |   |     | 30                             |      | 30             |      |                           |          |        |  |
| 40  |      |            | 40    |          | 40       |   |     | 40                             |      | 40             |      |                           |          |        |  |
| 50  |      |            | 50    |          | 50       |   |     | 50                             |      | 50             |      |                           |          |        |  |
| 60  |      |            | 60    |          | 60       |   |     | 60                             |      | 60             |      |                           |          |        |  |
|   |      |            |       |          |          | pH  |     |                                |      |                |      |                           |          |        |  |

Featherbed Nature Reserve Borehole 01\_ Borehole Capacity Testing Records\_R00


| FORM 5E  |          |            |      |  |       |          |          |                                    |          |                      |     |               |     |  |  |
|--|----------|------------|------|--|-------|----------|----------|------------------------------------|----------|----------------------|-----|---------------|-----|--|--|
| BOREHOLE TEST RECORD SHEET - CONSTANT DISCHARGE & RECOVERY |          |            |      |  |       |          |          |                                    |          |                      |     |               |     |  |  |
| Project No   |          | 01         |      |  |       |          |          |                                    |          | Province             |     | Western Cape  |     |  |  |
| Borehole No.   |          | 01         |      |  |       |          |          |                                    |          | Municipality         |     | Knysna        |     |  |  |
| Borehole Depth   |          | 82.00 mbgl |      |  |       |          |          |                                    |          | Coordinates          |     | 34° 4'26.56"S |     |  |  |
| Water Level  |          | 49.00 mbgl |      |  |       |          |          |                                    |          | Coordinates          |     | 23° 2'55.14"E |     |  |  |
| Depth of Pump  |          | 80.00 mbgl |      |  |       |          |          |                                    |          | Contractor           |     | Arena Group   |     |  |  |
| Casing   |          | 0.00       |      |  |       |          |          |                                    |          | Operator             |     | Jacques Fivaz |     |  |  |
| Elevation  |          | N/A        |      |  |       |          |          |                                    |          | Pump Type            |     | DW15M         |     |  |  |
| CONSTANT DISCHARGE & RECOVERY                              |          |            |      |  |       |          |          |                                    |          |                      |     |               |     |  |  |
| Test Started   |          |            |      | Duration   |       |          |          |                                    |          |                      |     |               |     |  |  |
| Date   |          | 26/03/2016 |      | Time   |       | 08H00    |          | 24.00                              |          | Hours                |     |               |     |  |  |
| Distance fom Observation Borehole                          |          |            |      | Observation Borehole   |       |          |          | None                               |          |                      |     |               |     |  |  |
| Distance fom Pumping Hole Borehole                         |          |            |      | None Applicable  |       |          |          | Distance from Observation Borehole |          |                      |     |               |     |  |  |
| CONSTANT DISCHARGE   |          |            |      |  |       | RECOVERY |          |                                    |          | Observation Borehole |     |               |     |  |  |
| Time   | Drawdown | Yield      | Time | Drawdown   | Yield | Time     | Drawdown | Time                               | Drawdown | Time                 | D/D | Time          | D/D |  |  |
| mins   | m        | L/S        | mins | m  | L/S   | mins     | m        | mins                               | m        | mins                 | m   | mins          | m   |  |  |
| 1  | 51,00    |            | 780  | 57,50  |       | 1        | 51,20    | 780                                |          | 1                    |     |               |     |  |  |
| 2  | 51,10    |            | 840  | 57,80  |       | 2        | 50,80    | 840                                |          | 2                    |     |               |     |  |  |
| 3  | 51,60    |            | 960  | 57,80  |       | 3        | 51,20    | 960                                |          | 3                    |     |               |     |  |  |
| 4  | 52,50    |            | 1080 | 57,50  |       | 4        | 51,10    | 1080                               |          | 4                    |     |               |     |  |  |
| 7  | 53,10    |            | 1200 | 57,50  |       | 7        | 51,10    | 1200                               |          | 5                    |     |               |     |  |  |
| 9  | 54,70    |            | 1440 | 57,50  |       | 9        | 51,00    | 1440                               |          | 7                    |     |               |     |  |  |
| 12   | 55,00    |            |      |  |       | 12       | 51,00    |                                    |          | 9                    |     |               |     |  |  |
| 15   | 55,30    |            |      |  |       | 15       | 51,00    |                                    |          | 12                   |     |               |     |  |  |
| 20   | 55,40    |            |      |  |       | 20       | 50,90    |                                    |          | 15                   |     |               |     |  |  |
| 25   | 55,80    |            |      |  |       | 25       | 50,90    |                                    |          | 20                   |     |               |     |  |  |
| 30   | 56,00    |            |      |  |       | 30       | 50,80    |                                    |          | 25                   |     |               |     |  |  |
| 40   | 56,10    |            |      |  |       | 40       | 50,80    |                                    |          | 30                   |     |               |     |  |  |
| 50   | 56,20    |            |      |  |       | 50       | 50,70    |                                    |          | 40                   |     |               |     |  |  |
| 60   | 56,50    |            |      |  |       | 60       | 50,70    |                                    |          | 50                   |     |               |     |  |  |
| 70   | 56,50    |            |      |  |       | 70       | 50,70    |                                    |          | 60                   |     |               |     |  |  |
| 80   | 56,50    |            |      |  |       | 80       | 50,70    |                                    |          | 70                   |     |               |     |  |  |
| 90   | 56,50    |            |      |  |       | 90       | 50,70    |                                    |          | 80                   |     |               |     |  |  |
| 120  | 56,60    |            |      |  |       | 120      |          |                                    |          | 90                   |     |               |     |  |  |
| 150  | 56,80    |            |      |  |       | 150      |          |                                    |          | 120                  |     |               |     |  |  |
| 180  | 56,80    |            |      |  |       | 180      |          |                                    |          | 150                  |     |               |     |  |  |
| 210  | 57,00    |            |      |  |       | 210      |          |                                    |          | 180                  |     |               |     |  |  |
| 240  | 57,00    |            |      |  |       | 240      |          |                                    |          | 210                  |     |               |     |  |  |
| 270  | 57,10    |            |      |  |       | 270      |          |                                    |          | 240                  |     |               |     |  |  |
| 300  | 57,20    |            |      |  |       | 300      |          |                                    |          | 270                  |     |               |     |  |  |
| 360  | 57,20    |            |      |  |       | 360      |          |                                    |          | 300                  |     |               |     |  |  |
| 420  | 57,20    |            |      |  |       | 420      |          |                                    |          | 360                  |     |               |     |  |  |
| 480  | 57,30    |            |      |  |       | 480      |          |                                    |          | 420                  |     |               |     |  |  |
| 540  | 57,30    |            |      |  |       | 540      |          |                                    |          | 480                  |     |               |     |  |  |
| 600  | 57,40    |            |      |  |       | 600      |          |                                    |          | 540                  |     |               |     |  |  |
| 660  | 57,40    |            |      |  |       | 660      |          |                                    |          | 600                  |     |               |     |  |  |
| 720  | 57,50    |            |      |  |       | 720      |          |                                    |          | 660                  |     |               |     |  |  |

# GEOHYDROLOGICAL INVESTIGATION REPORT

## *BOREHOLE CAPACITY AND WATER QUALITY TESTING*

*For*

### *FEATHERBED NATURE RESERVE BOREHOLE 02.*



**08<sup>th</sup> of April 2026**

**Report prepared by**

Baron Vutoyi (Pri. Sci.Nat. 120060)

+27 64 792 2504

[Vutoyi2012@gmail.com](mailto:Vutoyi2012@gmail.com)

**Report reviewed by**

Renaldo Taute

+27 60 640 3546

[sales3@arenagroup.co.za](mailto:sales3@arenagroup.co.za)

**Table of Contents**

|  |  |
|--|--|
| ACCEPTANCE LETTER.....   | 3  |
| PROFILE OF THE CONSULTANT .....                                    | 4  |
| 1. INTRODUCTION .....  | 5  |
| 1.1. Background .....  | 5  |
| 1.3. Geology of Featherbed Nature Reserve .....                    | 6  |
| 1.4. Hydrogeology .....  | 6  |
| 2. AQUIFER SUSTAINABILITY TESTING FOR BOREHOLES.....               | 7  |
| 2.1. Step Tests .....  | 7  |
| 2.2. Constant Discharge Test .....                                 | 7  |
| 2.3. Recovery Readings .....                                       | 7  |
| 3. AQUIFER TEST RESULTS FOR FEATHERBED NATURE RESERVE B/H 02. .... | 8  |
| 3.1. Step Testing Results .....                                    | 8  |
| 3.2. Constant discharge Test results .....                         | 9  |
| 3.3. Recovery testing results .....                                | 10   |
| 4. WATER QUALITY ANALYSIS.....                                     | 12   |
| 4.1. Sampling procedure .....                                      | 12   |
| 4.2. Water quality.....  | 12   |
| 5. CONCLUSIONS AND RECOMMENDATIONS .....                           | 13   |
| 5.1. RECOMMENDATIONS .....   | 13   |
| 5.2. CONCLUSIONS.....  | 13   |
| 6. REFERENCES .....  | 14   |
| APPENDIX A- BOREHOLE TEST RESULTS .....                            | 15   |
| <b>FEATHERBED NATURE RESERVE BOREHOLE 02 TEST RESULTS.....</b>     | <b>15</b>  |
| <br>   |  |
| <b>Figure</b>  |  |
| Figure 01  | Google Earth Location of Featherbed Nature Reserve B/H 02. 5                           |
| <br>   |  |
| <b>Graphs</b>  |  |
| Graph 1  | Graph of Step Drawdown Test of Featherbed Nature Reserve B/H 02. 8                     |
| Graph 2  | Graph of Constant Discharge test of Featherbed Nature Reserve B/H 02. 9                |
| Graph 3  | Graph of Derivative Plots And T- And S – Values Vs Log – Time B/H 02. 10               |
| Graph 4  | Graph of Recovery Test Vs Log – Time Of Featherbed Nature Reserve B/H 02 . 10          |
| <br>   |  |
| <b>Tables</b>  |  |
| Table 1  | Information of Featherbed Nature Reserve B/H 02. 8                                     |
| Table 2  | Drawdown Data - Step Test of Featherbed Nature Reserve B/H 02. 8                       |
| Table 3  | Drawdown - Constant Discharge Test Featherbed Nature Reserve B/H 02. 9                 |
| Table 4  | Drawdown Data Recovery & Step Test Recovery of Featherbed Nature Reserve B/H 02. 10    |
| Table 5  | Water Quality Analysis for Human Consumption of Featherbed Nature Reserve B/H 02. 11   |
| Table 6  | Recommended Installation and Abstraction Rate for Featherbed Nature Reserve B/H 02. 12 |

## ACCEPTANCE LETTER

26<sup>th</sup> of March 2026  
Corner of Rand & Bank Street  
George Industrial  
Western Cape, 6536

**Attention: Sir / Madam**

**Ref: Geohydrological Report for Featherbed Nature Reserve Borehole 01.**

Arena Group is pleased to present our Geohydrological Investigation Report for Featherbed Nature Reserve 01. This report contains a summary of the results of Borehole Capacity Testing and Water Quality Testing fieldwork investigation which was conducted on the 29<sup>th</sup> of March 2026 till the 31<sup>st</sup> of March 2026 by Arena Group.

We trust that this report contains the information required and we thank you for the opportunity to assist you on this project. Copies of Geohydrological Investigation Report have been distributed as indicate in the table below:

| <i>Distribution List</i>         | <i>Date issued</i> | <i>Number of Copies</i>    |
|----------------------------------|--------------------|----------------------------|
| <i>Mr. B. Vutoyi</i>             | 09/04/2026         | 1 Electronic and Hard Copy |
| <i>Arena Group</i>               | 09/04/2026         | 1 Electronic and Hard Copy |
| <i>Featherbed Nature Reserve</i> | 09/04/2026         | 1 Electronic and Hard Copy |

If you have any questions regarding the contents of this report, please call our office.

Yours Sincerely,



Baron Vutoyi

Geo hydrologist /Hydro Geologist (Pri. Sci. Nat Registered 120060)

**Tel:** 044 050 1151.

**Cell:** +27 64 792 2504.

**Email:** [vutoyi2012@gmail.com](mailto:vutoyi2012@gmail.com)

---

## PROFILE OF THE CONSULTANT

### GEO-HYDROLOGICAL CONSULTANT'S EXPERIENCE

- **Company** : Arena Group
- **Geo-Hydrological Consultant** : Baron Vutoyi
- **Telephone Number** :044 050 1151 / 086 999 0823
- **E-mail address** :[sales3@arenagroup.co.za](mailto:sales3@arenagroup.co.za)

### QUALIFICATIONS

- B.Sc. (Honours) Environmental Sciences, NWU, 2014.
- B.Sc. (Honours) Information Technology, NWU, 2011.
- B.Sc. Statistics & Geology, UZ, 2004,

### PROFESSIONAL REGISTRATION BOARDS

- SACNASP, Pri. Sci. Nat. 120060
- SAQA, NQF 7

### KEY EXPERIENCES:

- Project management, coordinating & supervising the work of professional and technical staff, designing, implementation, monitoring, communicating with the client & subcontractors through regular meetings, emails etc. and composing of concise technical reports for projects;
- Undertake specialist input into Basic Assessments, Environmental Impact Assessments, Water Use Licenses, Planning geophysical surveys and interpretation of data (obtained from Magnetometers, Electromagnetics, Resistivity etc.), Design and construction of production boreholes and monitoring wells in varied geological environments, Planning and execution of drilling, geological logging/mapping, camera inspection, hydraulic tests and interpretation of data, Data analysis and interpretation of hydro geochemical data, Understanding and experienced with conceptual hydrogeological models, numerical flow models;
- Ability to work in a multi-disciplinary team and an environment which promotes a high safety culture.

## 1. INTRODUCTION

### 1.1. Background

Following the appointment of Arena Group by Featherbed Nature Reserve (Pty) Ltd to conduct a borehole capacity and water quality testing to understand the aquifer yield and determine the correct pump to be installed. Four stages were conducted comprising of Step Testing, Constant Discharge Testing, Recovery Testing and Water Quality Testing to understand the sustainability / capacity of the borehole and hence make best possible recommendations for the borehole installation and usability. This study relied on expert knowledge and literature sources to assess and evaluate the current water resources and determine their productive capacity.

### 1.2. Location of the Borehole

A Google map showing the Featherbed Nature Reserve Borehole 02 location is presented below.



**Figure 01: Google Earth Location of Featherbed Nature Reserve Borehole 02.**

---

### 1.3. Geology of Featherbed Nature Reserve

The area and surrounding area of Featherbed Nature Reserve is underlain by rock formations of the Peninsula Formation, which form the base of the Table Mountain Group and the base of the Cape Supergroup. The Peninsula Formation is classified as Ordovician in age ( $\pm 480$  Ma). The Peninsula Formation (although not visible within this area specifically) was deposited on top of tilted and folded rocks of the Malmsbury Group and granites of the Cape Granite Suite and that it comprises at least half of the Table Mountain Group and its thickness varies from 1800 – 2150 m. It is composed of a monotonous succession of medium to coarse-grained, thickly bedded, greenish grey sandstone which weathers whitish.

The deposition was mainly from the north into the fairly stable basin. With time and as more and more layers of rock formations were deposited on top, and due to pressure and heat, these beach sands were metamorphosed into sandstone and eventually into quartzites.

### 1.4. Hydrogeology

The regional aquifer directly underlying the Featherbed Nature Reserve Borehole 02 is classified by the Department of Water Affairs and Forestry (DWAFF, 2002) as a fractured aquifer with an average yield potential of 0.1 – 0.5 L/s. A fractured aquifer describes an aquifer where groundwater only occurs in narrow fractures within the bedrock.

Based on the DWAFF (2002) mapping of the regional groundwater quality, the electrical conductivity (EC), the majority of the area surrounding the Featherbed Nature Reserve Borehole 02 is approximately to be in the range of 0 -70 mS/m. This is considered to be “moderate to poor” quality for water with respect to drinking water standards. Both these classifications are based on regional datasets, and therefore only provide an indication of conditions to be expected.

---

## 2. AQUIFER SUSTAINABILITY TESTING FOR BOREHOLES

Featherbed Nature Reserve Borehole 02 was aquifer tested by Arena Group. The test data has been analysed and is discussed below. In short, aquifer testing entails the following:

### 2.1. Step Tests

The borehole is pumped at varying abstraction rates for periods of 60 minutes each and water levels are measured in the borehole at pre-determined intervals. A recorded sheet is attached in the appendix. The test effectively stresses the hole and gives an indication of its capable yield. The abstraction rate for the longer duration aquifer sustainability test is determined from the step test and its resultant data; hence a blow yield of the borehole has to be identified.

### 2.2. Constant Discharge Test

The Constant Discharge Test is usually carried for a period of approximately 24-hours and involves measuring the water levels in the borehole while pumping the water out and thus creating "drawdown" within the borehole. Drawdown is the difference between the measured Water Level at any time during the test and the position at which the Water Level would have been Static Water Level (SWL) if abstraction had not taken place. The main aim of the test is to lower the Water Level in the borehole to approximately 65% of the Available Drawdown and maintain the Water Level at this depth. The Constant Discharge Test is performed to assess the productivity of the aquifer according to its response to the abstraction of water. The response is analysed to provide information regarding the hydraulic properties of the groundwater and arrive at an optimum yield for the medium to long-term utilization of the borehole.

### 2.3. Recovery Readings

The rate at which the borehole recovers (WL rises) is also measured and recorded once the pump is switched off. This data is useful in determine the storage available to the borehole and the position of the main water strike(s).

### 3. AQUIFER TEST RESULTS FOR FEATHERBED NATURE RESERVE B/H 02.

The details of the aquifer test set-ups of Featherbed Nature Reserve Borehole 02 are presented below;

#### 3.1. Step Testing Results


Table 1: Information of Featherbed Nature Reserve Borehole 02.

| Borehole Name             |               | Coordinates   |               | Borehole Information |  |
|---------------------------|---------------|---------------|---------------|----------------------|--|
| Site Name                 | Latitude      | Longitude     | B/H Depth (m) | SWL (m)              |  |
| Featherbed Nature Reserve | 34° 4'27.23"S | 23° 2'56.73"E | 73.00         | 48.40                |  |

Table 2: Drawdown Data - Step Test of Featherbed Nature Reserve Borehole 02.

| Steps   | L/s  | Depth of Pump (m) | Dynamic Water Level (m) | Available Drawdown (m) | Percentage of Drawdown (m) |
|---------|------|-------------------|-------------------------|------------------------|----------------------------|
| Step 01 | 0,50 | 70,00             | 48,40                   | 21,60                  | 30,86                      |
| Step 02 | 1,00 | 70,00             | 48,70                   | 21,30                  | 30,43                      |
| Step 03 | 1,50 | 70,00             | 49,20                   | 20,80                  | 29,71                      |
| Step 04 | 3,00 | 70,00             | 50,30                   | 19,70                  | 28,14                      |

Graph of Step Test Charge of the Borehole Vs Log – Time.



Graph 1: Graph of Step Drawdown Test of Featherbed Nature Reserve Borehole (B/H 01).

Analysis of the step-drawdown data indicated that the constant discharge test could be performed at a constant rate of 1,200 L/s for a period of twenty-four hours without failing.

### 3.2. Constant discharge Test results


**Table 3: Drawdown - Constant Discharge Test Featherbed Nature Reserve Borehole 02.**

| Constant Discharge | Duration Hours | Depth of Pump (m) | Static Water level (m) | Available Drawdown (m) | Dynamic Water Level (m) | Available Drawdown (m) | %age of Available Drawdown |
|--------------------|----------------|-------------------|------------------------|------------------------|-------------------------|------------------------|----------------------------|
| 1.20 L/s           | 24,00          | 70.00             | 48.40                  | 21.60                  | 49.70                   | 20.30                  | 93.98                      |

ALL calculation done above the static water level used is 48.40 mbgl and available drawdown is 21.60 mbgl after pump installation.

#### Graph of Constant Discharge Test of the Borehole Vs Log – Time.


Graph 2 below presents a graphical summary of the Constant Discharge Test and possible depth of water strikes that exists in the borehole 02



**Graph 2: Graph of Constant Discharge test of Featherbed Nature Reserve Borehole 02.**

The CDT was carried out for a period of a 24-hours at 1.20 L/s on average and achieved a maximum drawdown of 20.30 meters remained available which is 93.98 % of the available drawdown was available after constant discharge testing.

### Derivative Plots And T- And S – Values Vs Log – Time



**Graph 3: Graph of Derivative Plots And T- And S – Values Vs Log – Time**

The possible water strikes were identified at depth of 49.20 mbgl and 49.40 mbgl.

### 3.3. Recovery testing results


The recovery of the water level was monitored for both Step Test and CDT and is presented in the table below:

**Table 4: Drawdown Data Recovery and Step Test Recovery of Featherbed Nature Reserve Borehole 02.**

| Test          | Duration Minutes | Available Drawdown (m) | Static Water Level (m) | Dynamic Water Level (m) | Unrecovered | %age of recovered drawdown (m) |
|---------------|------------------|------------------------|------------------------|-------------------------|-------------|--------------------------------|
| Step Test     | 160              | 21,6                   | 48,4                   | 48,8                    | 0,4         | 98,14                          |
| Constant Test | 15               | 21,2                   | 48,8                   | 49,1                    | 0,3         | 98,58                          |

The step test water level in the borehole recovered to 98.14 % of the static water level in 160 minutes after pumping stopped and in the constant discharge test the water level in the borehole recovered to 98.58 % after the pump was switched off in fifteen minutes. In all the tests more than 65% of extracted water. This is an indication that the borehole recovers fast and has a good fracture network.

**Graph of Recovery Test of the Borehole Vs Log – Time.**



**Graph 3: Graph of Recovery Test Vs Log – Time of Featherbed Nature Reserve Borehole 02.**

It was observed that the borehole recovers very fast. Within an hour the borehole had recovered more than 65 % of the drawdown water pumped during constant discharge.

## 4. WATER QUALITY ANALYSIS

### 4.1. Sampling procedure

Groundwater samples are ideally collected and sent to a SANAS Accredited Laboratory (Western Cape Laboratory) for potability analysis. The sample are taken according to the DWAF standards, at the end of the Constant Discharge Test in order to be representative of the water of a wider zone around the borehole.

### 4.2. Water quality

Water quality of domestic water, utilized for human consumption and food preparation, must be safe to use if the consumers' health is to be protected. For this reason, the "Quality of Domestic Water Supplies" (Second edition, 1998)" was set forward by the Department of Water Affairs and Forestry, Department of Health and the Water Research Commission in 1998. This document facilitates the evaluation of water on the basis of five water quality classes:

**Table 5: Water Quality Analysis for Human Consumption,**

| CLASS   | pH            | TDS        | EC        | Total Hardness | Ca           | Mg         | Cl         | NO <sub>2</sub> | Na         | K         | F           |
|---------|---------------|------------|-----------|----------------|--------------|------------|------------|-----------------|------------|-----------|-------------|
| Class 0 | 5.00 - 9.50   | <450       | <70       | 0 -200         | 0.00 - 30.00 | <100       | <100       | <6              | <100       | <25       | <0.7        |
| Class 1 | 4.50 - 5.00   | 450 - 1000 | 70 - 150  | 200 - 300      | 30 - 150     | 100 - 200  | 100 - 200  | 6.00 - 10       | 100 - 200  | 25 - 50   | 0.70 - 1.00 |
| Class 2 | 4.00 - 4.50   | 1000 -2400 | 150 -370  | 300 - 400      | 150 - 300    | 200 - 400  | 200 - 600  | 10.00 - 20.00   | 200 - 400  | 50 - 100  | 1.00 - 1.50 |
| Class 3 | 3.00 - 4.00   | 2400-3400  | 370 - 520 | >400           | >300         | 400 - 1200 | 600 - 1200 | 20 - 40.00      | 400 - 1000 | 100 - 500 | 1.50 - 3.50 |
| Class 4 | <3.00 ->11.00 | >3400      | >520      |                |              | >1200      | >1200      | >40.00          | >1000      | >500      | >3.50       |

**Class 0 :** ideal water quality, suitable for lifetime.

**Class 1 :** Good water quality, suitable for use, rare instances of negative effects

**Class 2 :** Marginal water quality-conditionally acceptable, Negative effects may occur in some cases to sensitive groups .

**Class 3 :** Poor water quality, Unsuitable for use without treatment. Chronic effects may occur.

**Class 4 :** Dangerous water quality, totally unsuitable ,for use. Acute effects may occur.

However, there was no water sample collected and sent to the Water Laboratory for Water Quality Testing and analysis of the result. It is advisable that water quality is done depending on the water use.

This data should be analysed by a qualified Hydrogeologist to ensure long term sustainable use the of the borehole. The legal compliance regarding the use of the groundwater also needs to be addressed with the Department of Water and Sanitation.

## 5. CONCLUSIONS AND RECOMMENDATIONS

### 5.1. RECOMMENDATIONS

Based on the aquifer test data, assessing of the pumping curves, location of the borehole relative to other boreholes and the recovery data, the following abstraction and installation recommendations has been made:

| Table 6: Recommended Installation and Abstraction Rate for Featherbed Nature Reserve Borehole 02. |               |
|---|---------------|
| Borehole Depth  | 73,00 mbgl    |
| Borehole Pump Depth   | 70,00 mbgl    |
| Rest Water Level  | 48,40 mbgl    |
| Borehole Pumping Rate   | 1,20 L/s      |
| Borehole Pumping Duration   | 1 440 minutes |
| Borehole Recovery Duration  | 15 minutes    |
| Transducer  | Yes           |
| Litres per Second   | 1,20 L/s      |
| Litres per Minutes  | 72 L/s        |
| Litres per Hour   | 4 320 L/Hour  |
| Litres in 24 Hours  | 103 680 L/day |
| Critical Water Level  | 48,80 mbgl    |
| Dynamic Water Level   | 47,70 mbgl    |

### 5.2. CONCLUSIONS

As of January 2018 the Department of Water and Sanitation released a Government Gazette stating that: "All water use sector groups and individuals taking water from any water resource (surface or groundwater) regardless of the authorization type, in the Berg, Olifants and Breede Gouritz Water Management Area, shall install electronic water recording, monitoring or measuring devices to enable monitoring of abstractions, storage and use of water by existing lawful users and establish links with any monitoring or management system as well as keep records of the water used." Therefore, to facilitate monitoring and informed management of a borehole, it is highly recommended that a borehole be equipped with the following monitoring infrastructure and equipment:

- Installation of a 32 mm (inner diameter, class 10) observation pipe from the pump depth to the surface, closed at the bottom and slotted for the bottom 5 – 10 m. This

allows for a 'window' of access down the borehole which enables manual water level monitoring and can house an electronic water level logger.

- Installation of an electronic water level logger (for automated water level monitoring)
- Installation of a sampling tap (to monitor water quality) if required.
- Installation of a flow volume meter (to monitor abstraction rates and volumes)

## 6. REFERENCES

- ACOCKS, J.P.H., (1988). Veld Types of South Africa. Memoirs of the Botanical Survey of South Africa no. 57, 146pp.
- Buttner, S.H., Reid, W.K. & Erasmus, R. (2016). Late Permian tectonics and associated fluid influx during the Cape Orogeny: evidence from fault-bound quartz veins in the Wittenberg Group (Cape Super group, South Africa). South African Journal of Geology, Volume 119.2 Page 379- 398.
- DWAF (2002). The hydrogeological map series of the republic of South Africa. Scale: 1:500 000.
- Department of Water Affairs and Forestry (1999). Minimum Standards and Guidelines for Groundwater Resource Development for the Community Water Supply and Sanitation Programme. (First Edition).
- HEM, J.D. (1970). Study and interpretation of the chemical characteristics of natural water. 2nd edition. U.S Geol. Survey. Water Supply Paper 1473, 363pp.
- Holmes, P, J, Marker, M. 2002: The Distribution and Environmental Implications of Cover sand Deposits in the Southern Cape, South Africa. South African Journal of Geology, 2002, 105, (135146).
- National water act (1998). The national water act, NO 36. Department of Water Affairs and Forestry. Pretoria.
- MIDGLEY, D.C., PITMAN, W.V., MIDDLETON, B.J. (1994). Surface water resources of South Africa 1990. WRC Report no 298/6.2/94, Vol. V1 Appendices (First edition).



[sales3@arenagroup.co.za](mailto:sales3@arenagroup.co.za)

---

**ARENA GROUP**

Corner of Rand and Bank Street  
George Industrial, Western Cape, 6536  
+27 (086) 999 0823, +27 (044) 050 1151

## **APPENDIX A- BOREHOLE TEST RESULTS**

### ***FEATHERBED NATURE RESERVE BOREHOLE 02 TEST RESULTS***

| FORM 5F   |             |       |      |   |                                |                           |       |                |             |             |       |       |      |          |
|---|-------------|-------|------|---|--------------------------------|---------------------------|-------|----------------|-------------|-------------|-------|-------|------|----------|
| BOREHOLE TEST RECORD SHEET - STEP TEST DISCHARGE & RECOVERY |             |       |      |   |                                |                           |       |                |             |             |       |       |      |          |
| Alt Borehole  | None        |       |      |  | Province                       | Western Cape              |       |                |             |             |       |       |      |          |
| Alt Borehole  | None        |       |      |   | District                       | Kysna Municipality        |       |                |             |             |       |       |      |          |
| Depth of Borehole   | None        |       |      |   | Site Name                      | Featherbed Nature Reserve |       |                |             |             |       |       |      |          |
|   |             |       |      | Date  | 28 <sup>th</sup> of March 2026 |                           |       |                |             |             |       |       |      |          |
| Borehole Depth  | 73.00 mbgl  |       |      | Datum Level Above Casing (m)  | 0.90                           |                           |       | Pump Installed | Submersible |             |       |       |      |          |
| Water Level   | 48.400 mbgl |       |      | Casing Height (magl)  | 0.00                           |                           |       | Contractor     | Arena Group |             |       |       |      |          |
| Depth of Pump   | 70.00 mbgl  |       |      | Diameter of the Pump (mm)   | 160.00                         |                           |       | Pump Type      | DW15M       |             |       |       |      |          |
| STEP TEST & RECOVERY  |             |       |      |   |                                |                           |       |                |             |             |       |       |      |          |
| Discharge 1   |             |       |      |   | Discharge 2                    |                           |       |                |             | Discharge 3 |       |       |      |          |
| Date:   | Time        |       |      |   | Date:                          | Time                      |       |                |             | Date:       | Time  |       |      |          |
| Time  | D/D         | Yield | Time | Recovery  | Time                           | D/D                       | Yield | Time           | Recovery    | Time        | D/D   | Yield | Time | Recovery |
| mins  | m           | L/s   | mins | m   | mins                           | m                         | L/s   | mins           | m           | mins        | m     | L/s   | mins | m        |
| 1   | 48.30       | 0.50  | 1    |   | 1                              | 48.40                     | 1.00  | 1              |             | 1           | 48.80 | 1.50  | 1    | 49.400   |
| 2   | 48.10       | 0.50  | 2    |   | 2                              | 48.40                     | 1.00  | 2              |             | 2           | 48.80 | 1.50  | 2    | 49.200   |
| 3   | 48.10       | 0.50  | 3    |   | 3                              | 48.40                     | 1.00  | 3              |             | 3           | 48.90 | 1.50  | 3    | 49.100   |
| 4   | 48.20       | 0.50  | 4    |   | 4                              | 48.40                     | 1.00  | 4              |             | 4           | 49.10 | 1.50  | 5    | 49.100   |
| 5   | 48.20       | 0.50  | 5    |   | 5                              | 48.40                     | 1.00  | 5              |             | 5           | 49.10 | 1.50  | 7    | 49.100   |
| 6   | 48.20       | 0.50  | 6    |   | 6                              | 48.50                     | 1.00  | 6              |             | 6           | 49.10 | 1.50  | 10   | 49.100   |
| 7   | 48.20       | 0.50  | 7    |   | 7                              | 48.50                     | 1.00  | 7              |             | 7           | 49.10 | 1.50  | 15   | 49.100   |
| 9   | 48.20       | 0.50  | 9    |   | 9                              | 48.50                     | 1.00  | 9              |             | 9           | 49.10 | 1.50  | 20   | 48.900   |
| 12  | 48.20       | 0.50  | 12   |   | 12                             | 48.50                     | 1.00  | 12             |             | 12          | 49.10 | 1.50  | 30   | 48.900   |
| 15  | 48.30       | 0.50  | 15   |   | 15                             | 48.50                     | 1.00  | 15             |             | 15          | 49.10 | 1.50  | 40   | 48.900   |
| 20  | 48.30       | 0.50  | 20   |   | 20                             | 48.60                     | 1.00  | 20             |             | 20          | 49.10 | 1.50  | 50   | 48.900   |
| 25  | 48.40       | 0.50  | 25   |   | 25                             | 48.60                     | 1.00  | 25             |             | 25          | 49.10 | 1.50  | 60   | 48.900   |
| 30  | 48.40       | 0.50  | 30   |   | 30                             | 48.60                     | 1.00  | 30             |             | 30          | 49.10 | 1.50  | 70   | 48.800   |
| 40  | 48.40       | 0.50  | 40   |   | 40                             | 48.60                     | 1.00  | 40             |             | 40          | 49.10 | 1.50  | 80   | 48.800   |
| 50  | 48.40       | 0.50  | 50   |   | 50                             | 48.60                     | 1.00  | 50             |             | 50          | 49.10 | 1.50  | 90   | 48.800   |
| 60  | 48.40       | 0.50  | 60   |   | 60                             | 48.70                     | 1.00  | 60             |             | 60          | 49.20 | 1.50  | 100  | 48.800   |

Featherbed Nature Reserve Borehole 02\_ Borehole Capacity Testing Records\_R00

| FORM 5F   |       |             |          |          |   |      |                                |          |          |                |      |                           |          |          |
|---|-------|-------------|----------|----------|---|------|--------------------------------|----------|----------|----------------|------|---------------------------|----------|----------|
| BOREHOLE TEST RECORD SHEET - STEP TEST DISCHARGE & RECOVERY |       |             |          |          |   |      |                                |          |          |                |      |                           |          |          |
| Alt Borehole  |       | None        |          |          |  |      |                                |          |          | Province       |      | Western Cape              |          |          |
| Alt Borehole  |       | None        |          |          |   |      |                                |          |          | District       |      | Krynsna Municipality      |          |          |
| Depth of Borehole   |       | None        |          |          |   |      |                                |          |          | Site Name      |      | Featherbed Nature Reserve |          |          |
|   |       |             |          |          | Date  |      | 28 <sup>th</sup> of March 2026 |          |          |                |      |                           |          |          |
| Borehole Depth  |       | 73.00 mbgl  |          |          | Datum Level Above Casing (m)  |      | 0.90                           |          |          | Pump Installed |      | Submersible               |          |          |
| Water Level   |       | 48.400 mbgl |          |          | Casing Height (magl)  |      | 0.00                           |          |          | Contractor     |      | Arena Group               |          |          |
| Depth of Pump   |       | 70.00 mbgl  |          |          | Diameter of the Pump (mm)   |      | 160.00                         |          |          | Pump Type      |      | DW15M                     |          |          |
| Date:   | Time  |             | Recovery |          | Date:   | Time |                                | Recovery |          | Date:          | Time |                           | Recovery |          |
| Time  | D/D   | Yield       | Time     | Recovery | Time  | D/D  | Yield                          | Time     | Recovery | Time           | D/D  | Yield                     | Time     | Recovery |
| mins  | m     | L/s         | mins     | m        | mins  | m    | L/s                            | mins     | m        | mins           | m    | L/s                       | mins     | M        |
| 1   | 49.40 | 3.00        | 1        |          | 1   |      |                                | 1        |          | 1              |      |                           | 120      | 48.800   |
| 2   | 49.60 | 3.00        | 2        |          | 2   |      |                                | 2        |          | 2              |      |                           | 150      | 48.800   |
| 3   | 49.70 | 3.00        | 3        |          | 3   |      |                                | 3        |          | 3              |      |                           | 180      | 48.800   |
| 4   | 49.80 | 3.00        | 4        |          | 4   |      |                                | 4        |          | 4              |      |                           |          |          |
| 5   | 49.80 | 3.00        | 5        |          | 5   |      |                                | 5        |          | 5              |      |                           |          |          |
| 6   | 49.90 | 3.00        | 6        |          | 6   |      |                                | 6        |          | 6              |      |                           |          |          |
| 7   | 49.90 | 3.00        | 7        |          | 7   |      |                                | 7        |          | 7              |      |                           |          |          |
| 9   | 49.90 | 3.00        | 9        |          | 9   |      |                                | 9        |          | 9              |      |                           |          |          |
| 12  | 50.00 | 3.00        | 12       |          | 12  |      |                                | 12       |          | 12             |      |                           |          |          |
| 15  | 50.00 | 3.00        | 15       |          | 15  |      |                                | 15       |          | 15             |      |                           |          |          |
| 20  | 50.00 | 3.00        | 20       |          | 20  |      |                                | 20       |          | 20             |      |                           |          |          |
| 25  | 50.10 | 3.00        | 25       |          | 25  |      |                                | 25       |          | 25             |      |                           |          |          |
| 30  | 50.10 | 3.00        | 30       |          | 30  |      |                                | 30       |          | 30             |      |                           |          |          |
| 40  | 50.20 | 3.00        | 40       |          | 40  |      |                                | 40       |          | 40             |      |                           |          |          |
| 50  | 50.30 | 3.00        | 50       |          | 50  |      |                                | 50       |          | 50             |      |                           |          |          |
| 60  | 50.30 | 3.00        | 60       |          | 60  |      |                                | 60       |          | 60             |      |                           |          |          |
|   |       |             |          |          | pH  |      |                                |          |          |                |      |                           |          |          |

Featherbed Nature Reserve Borehole 02\_ Borehole Capacity Testing Records\_R00

| FORM 5E  |          |             |      |  |       |          |          |                                    |          |                      |     |               |     |  |  |
|--|----------|-------------|------|--|-------|----------|----------|------------------------------------|----------|----------------------|-----|---------------|-----|--|--|
| BOREHOLE TEST RECORD SHEET - CONSTANT DISCHARGE & RECOVERY |          |             |      |  |       |          |          |                                    |          |                      |     |               |     |  |  |
| Project No   |          | 01          |      |  |       |          |          |                                    |          | Province             |     | Western Cape  |     |  |  |
| Borehole No.   |          | 02          |      |  |       |          |          |                                    |          | Municipality         |     | Knysna        |     |  |  |
| Borehole Depth   |          | 73.00 mbgl  |      |  |       |          |          |                                    |          | Coordinates          |     | 34° 4'26.62"S |     |  |  |
| Water Level  |          | 48.800 mbgl |      |  |       |          |          |                                    |          | Coordinates          |     | 23° 2'55.38"E |     |  |  |
| Depth of Pump  |          | 70.00 mbgl  |      |  |       |          |          |                                    |          | Contractor           |     | Arena Group   |     |  |  |
| Casing   |          | 0.00        |      |  |       |          |          |                                    |          | Operator             |     | Jacques Fivaz |     |  |  |
| Elevation  |          | N/A         |      |  |       |          |          |                                    |          | Pump Type            |     | DW15M         |     |  |  |
| CONSTANT DISCHARGE & RECOVERY                              |          |             |      |  |       |          |          |                                    |          |                      |     |               |     |  |  |
| Test Started   |          |             |      | Duration   |       |          |          |                                    |          |                      |     |               |     |  |  |
| Date   |          | 28/03/2016  |      | Time   |       | 08H00    |          | 24.00                              |          | Hours                |     |               |     |  |  |
| Distance fom Observation Borehole                          |          |             |      | Observation Borehole   |       |          |          | None                               |          |                      |     |               |     |  |  |
| Distance fom Pumping Hole Borehole                         |          |             |      | None Applicable  |       |          |          | Distance from Observation Borehole |          |                      |     |               |     |  |  |
| CONSTANT DISCHARGE   |          |             |      |  |       | RECOVERY |          |                                    |          | Observation Borehole |     |               |     |  |  |
| Time   | Drawdown | Yield       | Time | Drawdown   | Yield | Time     | Drawdown | Time                               | Drawdown | Time                 | D/D | Time          | D/D |  |  |
| mins   | m        | L/S         | mins | m  | L/S   | mins     | m        | mins                               | m        | mins                 | m   | mins          | m   |  |  |
| 1  | 48,10    |             | 780  | 49,80  |       | 1        | 51,20    | 780                                |          | 1                    |     |               |     |  |  |
| 2  | 48,60    |             | 840  | 49,80  |       | 2        | 50,80    | 840                                |          | 2                    |     |               |     |  |  |
| 3  | 48,90    |             | 960  | 49,80  |       | 3        | 51,20    | 960                                |          | 3                    |     |               |     |  |  |
| 4  | 49,00    |             | 1080 | 49,80  |       | 4        | 51,10    | 1080                               |          | 4                    |     |               |     |  |  |
| 7  | 49,10    |             | 1200 | 49,80  |       | 7        | 51,10    | 1200                               |          | 5                    |     |               |     |  |  |
| 9  | 49,20    |             | 1440 | 49,80  |       | 9        | 51,00    | 1440                               |          | 7                    |     |               |     |  |  |
| 12   | 49,20    |             |      |  |       | 12       | 51,00    |                                    |          | 9                    |     |               |     |  |  |
| 15   | 49,20    |             |      |  |       | 15       | 51,00    |                                    |          | 12                   |     |               |     |  |  |
| 20   | 49,30    |             |      |  |       | 20       | 50,90    |                                    |          | 15                   |     |               |     |  |  |
| 25   | 49,40    |             |      |  |       | 25       | 50,90    |                                    |          | 20                   |     |               |     |  |  |
| 30   | 49,40    |             |      |  |       | 30       | 50,80    |                                    |          | 25                   |     |               |     |  |  |
| 40   | 49,40    |             |      |  |       | 40       | 50,80    |                                    |          | 30                   |     |               |     |  |  |
| 50   | 49,40    |             |      |  |       | 50       | 50,70    |                                    |          | 40                   |     |               |     |  |  |
| 60   | 49,50    |             |      |  |       | 60       | 50,70    |                                    |          | 50                   |     |               |     |  |  |
| 70   | 49,60    |             |      |  |       | 70       | 50,70    |                                    |          | 60                   |     |               |     |  |  |
| 80   | 49,60    |             |      |  |       | 80       | 50,70    |                                    |          | 70                   |     |               |     |  |  |
| 90   | 49,60    |             |      |  |       | 90       | 50,70    |                                    |          | 80                   |     |               |     |  |  |
| 120  | 49,60    |             |      |  |       | 120      |          |                                    |          | 90                   |     |               |     |  |  |
| 150  | 49,60    |             |      |  |       | 150      |          |                                    |          | 120                  |     |               |     |  |  |
| 180  | 49,60    |             |      |  | 4     | 180      |          |                                    |          | 150                  |     |               |     |  |  |
| 210  | 49,70    |             |      |  |       | 210      |          |                                    |          | 180                  |     |               |     |  |  |
| 240  | 49,70    |             |      |  |       | 240      |          |                                    |          | 210                  |     |               |     |  |  |
| 270  | 49,70    |             |      |  |       | 270      |          |                                    |          | 240                  |     |               |     |  |  |
| 300  | 49,70    |             |      |  |       | 300      |          |                                    |          | 270                  |     |               |     |  |  |
| 360  | 49,70    |             |      |  |       | 360      |          |                                    |          | 300                  |     |               |     |  |  |
| 420  | 49,80    |             |      |  |       | 420      |          |                                    |          | 360                  |     |               |     |  |  |
| 480  | 49,80    |             |      |  |       | 480      |          |                                    |          | 420                  |     |               |     |  |  |
| 540  | 49,80    |             |      |  |       | 540      |          |                                    |          | 480                  |     |               |     |  |  |
| 600  | 49,80    |             |      |  |       | 600      |          |                                    |          | 540                  |     |               |     |  |  |
| 660  | 49,80    |             |      |  |       | 660      |          |                                    |          | 600                  |     |               |     |  |  |
| 720  | 49,80    |             |      |  |       | 720      |          |                                    |          | 660                  |     |               |     |  |  |



## Certificate of Analysis

| <b>Client</b>                                 | Arena Group   |          |  |                                  |
|---|---|----------|--|----------------------------------|
| <b>Reference</b>                              | Featherbed Borehole 1                               |          |  |                                  |
| <b>Date of Certificate</b>                    | 07-Apr-26   |          |  |                                  |
| <b>Sample Type</b>                            | Borehole  |          |  |                                  |
| Parameters                                    | Test Methods  | Borehole |  | SANS 241 Drinking Water Standard |
|   |   | 1        |  |                                  |
| * pH  | HANNA HI8424  | 6.97     |  | 5.0 - 9.5                        |
| * Electrical Conductivity (mS/m)              | WTW LF330   | 54       |  | <150                             |
| * Turbidity (NTU)                             | HACH 2100P  | 0.74     |  | < 1.0                            |
| * Colour                                      | HACH Method 8225                                    | 2        |  | < 20                             |
| * Iron (mg/L as Fe)                           | HACH Method 8008                                    | 0.00     |  | 0.20                             |
| * Aluminium (mg/L as Al)                      | HACH Method 8012                                    | 0.016    |  | 0.30                             |
| * Total Hardness (mg/L as CaCO <sub>3</sub> ) | HACH Method 8226                                    | 98       |  | <500                             |
| * Calcium (mg/L as CaCO <sub>3</sub> )        | HACH Method 8222                                    | 63       |  | <150                             |
| * Calcium as Ca                               | Calculated  | 25.3     |  | < 150                            |
| * Magnesium (mg/L as MgCO <sub>3</sub> )      | HACH Method 8222                                    | 35       |  | <70                              |
| * Magnesium as Mg                             | Calculated  | 10.1     |  | < 70                             |
| * Total Dissolved Solids (mg/l)               | Calculated  | 348      |  | < 1200                           |
| * Alkalinity (mg/ L)                          | Titrations  | 52       |  | <500                             |
| * Sulphate Mg/L)                              | Sulfaver 4 Method 8051                              | 11       |  | < 400                            |
| * Manganese (Mn) (mg/ L)                      | HACH Method 8149 PAN Method                         | 0.022    |  | 0.100                            |
| * Chloride ( mg/l )                           | Method 8225, Silver Nitrate Method, Buret Titration | 73       |  | < 300                            |
| * Fluoride (mg/ L)                            | Hach Method SPADNS Method                           | 0.16     |  | < 1.0                            |
| * Total Coliforms (Count/100ml)               | Membrane filtration                                 | 600      |  | 0                                |
| * E.Coli Count/100ml)                         | Membrane filtration                                 | Nil      |  | 0                                |

***The values in red prevented the water to comply with the SANS 241 Drinking Water Standards.***

Instrument calibration are done daily with appropriate standards

Laboratory Chemical Analysis Code: Western Cape Laboratory Services SABS Lab Code: B211

Instrument Calibration: Group 1 – 3 / Heavy Metals/Nutrients/Major Constituents

*This report relates only to the samples analysed by the consultancy. It does not accept responsibility for any matter arising from further use of these results, other than that recommended in the report.*



## Certificate of Analysis

| <b>Client</b>                                 | Arena Group   |          |  |                                  |
|---|---|----------|--|----------------------------------|
| <b>Reference</b>                              | Featherbed 2  |          |  |                                  |
| <b>Date of Certificate</b>                    | 13-Apr-26   |          |  |                                  |
| <b>Sample Type</b>                            | Borehole  |          |  |                                  |
| Parameters                                    | Test Methods  | Borehole |  | SANS 241 Drinking Water Standard |
|   |   | 2        |  |                                  |
| * pH  | HANNA HI8424  | 7.32     |  | 5.0 - 9.5                        |
| * Electrical Conductivity (mS/m)              | WTW LF330   | 36       |  | <150                             |
| * Turbidity (NTU)                             | HACH 2100P  | 0.5      |  | < 1.0                            |
| * Colour                                      | HACH Method 8225                                    | 0        |  | < 20                             |
| * Iron (mg/L as Fe)                           | HACH Method 8008                                    | 0.09     |  | 0.20                             |
| * Aluminium (mg/L as Al)                      | HACH Method 8012                                    | 0.008    |  | 0.30                             |
| * Total Hardness (mg/L as CaCO <sub>3</sub> ) | HACH Method 8226                                    | 74       |  | <500                             |
| * Calcium (mg/L as CaCO <sub>3</sub> )        | HACH Method 8222                                    | 51       |  | <150                             |
| * Calcium as Ca                               | Calculated  | 20.4     |  | < 150                            |
| * Magnesium (mg/L as MgCO <sub>3</sub> )      | HACH Method 8222                                    | 23       |  | <70                              |
| * Magnesium as Mg                             | Calculated  | 6.6      |  | < 70                             |
| * Total Dissolved Solids (mg/l)               | Calculated  | 232      |  | < 1200                           |
| * Alkalinity (mg/ L)                          | Titrations  | 37       |  | <500                             |
| * Sulphate Mg/L)                              | Sulfaver 4 Method 8051                              | 3        |  | < 400                            |
| * Manganese (Mn) (mg/ L)                      | HACH Method 8149 PAN Method                         | 0.060    |  | 0.100                            |
| * Chloride ( mg/l )                           | Method 8225, Silver Nitrate Method, Buret Titration | 68       |  | < 300                            |
| * Fluoride (mg/ L)                            | Hach Method SPADNS Method                           | 0.41     |  | < 1.0                            |
| * Total Coliforms (Count/100ml)               | Membrane filtration                                 | 400      |  | 0                                |
| * E.Coli Count/100ml)                         | Membrane filtration                                 | Nil      |  | 0                                |

**The values in red prevented the water to comply with the SANS 241 Drinking Water Standards.**

Instrument calibration are done daily with appropriate standards


Laboratory Chemical Analysis Code: Western Cape Laboratory Services SABS Lab Code: B211

Instrument Calibration: Group 1 – 3 / Heavy Metals/Nutrients/Major Constituents

*This report relates only to the samples analysed by the consultancy. It does not accept responsibility for any matter arising from further use of these results, other than that recommended in the report.*



**PROPOSED MODULAR 65KL WASTEWATER TREATMENT PLANT  
FEATHERBED RESERVE – KNYSNA REF. BBAG60GL FB KL250326**



Kevi Levin



## CONTENTS:

Page 1. CONTENTS.

Page 2. SECTION 1 - Client Details.

Page 3. SECTION 2 – Info. Provided & Scope of Works.

Page 4. SECTION 3. - Treated Effluent Quality.

Page 5. SECTION 4. - Incoming Effluent.

Page 6 - 8. SECTION 5. - Process Overview & Equipment.

Page 7 - SECTION 6. – Previous Installations.

Page 8. SECTION 7. - Maintenance Requirements.

Page 8. SECTION 8. – Operating Costs.

Page 8. SECTION 9. – Electrical Requirements.

Page 9. SECTION 10. - Installation.

Page 9. SECTION 11. – Delivery and Offloading.

Page 10. SECTION 12. – HSEQ Requirements.

Page 10. SECTION 13. – Customer Responsibilities.

Page 10. SECTION 14. – Guarantees.

Page 11. SECTION 15. – Inclusions to the Offer.

Page 11. SECTION 16. – Exclusions to the Offer.

Page 11. SECTION 17. – General Terms & Conditions.

Page 12. SECTION 18. – Lead Times.

Page 12. SECTION 19. – Payment Terms.

Page 12. SECTION 20. – Cost Proposal.



**SECTION 1. CLIENT DETAILS.**

|  |
|--|
| FEATHERBED RESERVE                                     |
| Represented by Mr. Rein Hofmeyr of Hofmeyr Associates. |



## SECTION 2. INFO. PROVIDED AND SCOPE OF WORKS.

The client is in possession of an existing treatment plant, which is currently non-operational.

After inspection of the plant, and assessing its suitability for the treatment of effluent, we report back as follows:

1. The plant is not compliant in any way for treatment of sewage,
2. The capacity of current plant cannot handle the required load of 65m<sup>3</sup>/day as requested by the client,
3. The current tanks are not suited for this application, as they are water tanks, and not suited to a volatile substance such as domestic effluent. Furthermore the existing drilling on the tanks would make it very difficult to convert or modify them, even if they were suited to the application.
4. Effluent in any form requires specific Chemical Grade tanks,
5. The aeration system is in-operational, and rusted beyond repair,
6. It does not seem that there is any Pall Ring media in the aerobic tanks, which is critical to the chemical process,
7. There is no disinfection dosing capability on the tanks,
8. The effluent being discharged into the environment does not conform to legislative requirements and is hazardous to the environment.
9. Should any official inspect the plant, the client will be liable for legislative action.

We would thus propose that a new, built to purpose plant which will provide the required standard of effluent be installed, utilising as much of the current mechanical and electrical infra-structure as possible. This includes the current receiving tanks and transfer pump and pipeline at the restaurant area, as well as the discharge pump, and control panel, with necessary modifications.



**The scope of works is as follows:**

- **Inlet works**
  - Screening of raw sewage and collection of inorganic matter in an existing septic tank provided, before treatment process commences.
  - Able to handle peak flows.
  - The current transfer pump is to be utilised as is. This pump will transfer fluids from the initial septic phase to the buffer tank before the plant' phase to the plant.
- **Package Plant**
  - Able to biologically remove organic material, nitrogen, and phosphate.
  - Constructed out of durable H.D.P.E. Chemical Grade Tanks material
  - Meet effluent discharge standards – D.W.S. General Standards.
  - Provide specifications for operation and maintenance requirements.
  - Provide critical spares equipment list.
  - Provide operation and maintenance costing.
  - The appropriate sewage flow rate and discharge requirement are estimated at 65kl/day, as provided by the client.
  - Provide disinfection facilities to meet required effluent criteria.
  - Release treated wastewater into the environment. It is the client's responsibility to transfer the treated effluent to the discharge point required.
- **Costing**
  - Delivery and installation of complete packaged plant.
  - All capital cost involved in supplying packaged plant,
  - Provide costs of Maintenance.
  - .



## SECTION 3. INFLUENT & TREATED EFFLUENT QUALITY.

This final effluent is guaranteed to be within General Limits as required from South African DWS.  
 All our plants are measured against below Parameters.

| Influent Parameters assumed - max. allowed |                     |  |                        |
|--|---------------------|--|------------------------|
| Determinant                                | Unit                | Typical domestic wastewater max. assumed |                        |
| COD  | mgO <sub>2</sub> /ℓ | 700                                      |                        |
| Suspended solids                           | mg/ℓ                | 350                                      |                        |
| TKN  | mg/ℓ                | 85                                       |                        |
| Phosphate                                  | mg/ℓ                | 13                                       |                        |
| Ammonia                                    | mg/ℓ                | 60                                       |                        |
|  |                     |  |                        |
| Treated Effluent Parameters Required       |                     |  |                        |
| Determinant                                | Unit                | Value - General Limits                   | Value - Special Limits |
| COD  | mgO <sub>2</sub> /ℓ | 75.0                                     | 30.0                   |
| Suspended solids                           | mg/ℓ                | 25.0                                     | 10.0                   |
| TKN  | mg/ℓ                | 15.0                                     | 1.5                    |
| Phosphate                                  | mg/ℓ                | 10.0                                     | 2.5                    |
| Ammonia                                    | mg/ℓ                | 3.0                                      | 2.0                    |



## SECTION 4. TECHNICAL CALCULATIONS


| Plant Specific Calculations             |                     |                                      |
|---|---------------------|--------------------------------------|
| Q - Daily influent rate                 | m <sup>3</sup> /d   | 60                                   |
| B.O.D.                                  | mg/l                | 300                                  |
| C.O.D.                                  | mg/l                | 75.0                                 |
| f = Oxygen equivalent factor            |                     | 1                                    |
| O <sub>2</sub> transfer efficiency (E): | %                   | 25%                                  |
| O <sub>2</sub> % in air:                | %                   | 21%                                  |
| Density of air at STP -                 | kg/m <sup>3</sup>   | 1.225                                |
| Oxygen requirement                      |                     |                                      |
| O <sup>2</sup> -calculated              | kg/d                | 18                                   |
| Assumed overall transfer efficiency     | %                   | 10                                   |
| Required process air                    | kg/d                | 640                                  |
| Duration of pumping                     | hr/d                | 8                                    |
| Blower capacity                         | m <sup>3</sup> /hr  | 80                                   |
| Blower duty and size                    |                     |                                      |
| Water Depth                             | kPa                 | 30                                   |
| Allow for losses                        | kPa                 | 10                                   |
| Total ΔP                                | kPa                 | 40                                   |
| Air Flow                                | m <sup>3</sup> /sec | 0.022                                |
| Efficiency (Blower & Motor)             | Watts               | 1.48                                 |
| Required Blower Duty                    |                     | 80m <sup>3</sup> /hr/40kPa           |
| Motor Size                              | Kw                  | 2.2 allowing for margin and turndown |
| Retention duration applied:             |                     |                                      |
| Daily Influent Rate:                    | m <sup>3</sup> /day | 60                                   |
| <b>Determinant</b>                      | <b>hrs.</b>         | <b>General Limits</b>                |
| Hydraulic Retention time - Buffer       | hrs.                | 4                                    |
| Hydraulic Retention time - Anaerobic    | hrs.                | 30                                   |
| Hydraulic Retention time - Aerobic      | hrs.                | 24                                   |
| Hydraulic Retention time - Clarifier    | hrs.                | 17                                   |
| Hydraulic Retention time - Disinfection | hrs.                | 1                                    |
| Calculated Chamber Capacities           |                     |                                      |
| Buffer                                  | m <sup>3</sup>      | 10                                   |
| Anaerobic                               | m <sup>3</sup>      | 75                                   |
| Aerobic                                 | m <sup>3</sup>      | 60                                   |
| Clarifier                               | m <sup>3</sup>      | 42.5                                 |
| Disinfection                            | m <sup>3</sup>      | 2.5                                  |



| <b>Chamber Capacities Rounded for Practicality</b> |                                |                       |
|--|--------------------------------|-----------------------|
| Buffer   | m3                             | 10                    |
| Anaerobic incl. Buffer                             | m3                             | 50                    |
| Aerobic  | m3                             | 60                    |
| Clarifier  | m3                             | 40                    |
| Disinfection                                       | m3                             | 2.5                   |
| <b>Aeration Media Norms</b>                        |                                |                       |
| Type   | mm                             | 100mm Pall Ring Media |
| Surface Area                                       | mm <sup>2</sup>                | 71667.85              |
| Mass   | g                              | 36.3                  |
| Surface area/m <sup>3</sup>                        | m <sup>2</sup> /m <sup>3</sup> | 200.39                |
| Calculated Units                                   | units/m <sup>2</sup>           | 1960                  |
| Density  | g/cm <sup>3</sup>              | 1.24 min.             |
| Void Ratio   | %                              | 91.79                 |
| Quantity required                                  | item                           | 117600                |



## SECTION 5. PROCESS OVERVIEW & EQUIPMENT.



### **Anaerobic digestion tanks and Buffer (New tanks)**

- The effluent will flow into an above-ground by pumping from the existing septic tanks,
- The anaerobic treatment processes take place in the absence of air (and thus molecular/free of oxygen) by those microorganisms (also called anaerobes) which do not require air (molecular/free oxygen) to assimilate organic impurities. The final products of organic assimilation in anaerobic treatment are methane and carbon dioxide gas and biomass.
- The anaerobic digestion also serves as separation of solids from liquids, a dual function which allows for settlement of solids and the other solids like oils, fats and greases will float to surface.
- The anaerobic digester also allows for anoxic conditions where nitrogen is removed.
- Hydraulic retention: 1 Day

### **Aerobic digestion or Bioreactors (New tanks)**

- The Anaerobic phase will flow through to the Aerobic phase via gravity.
- The aerobic phase makes use of multiple lined tanks in series to serve as the aerobic digestion phase. Each tank will be fitted with diffusers supplied with air by blowers, which allows for high dissolved oxygen transfer into the effluent.
- Fixed film media to be installed in the tank to allow for bacterial growth at a rate of > 148m<sup>2</sup>/m<sup>3</sup> of surface area
- Hydraulic retention: 1 Day

### **Clarifier or Re-activated sludge (RAS) tank (New tanks)**

- There will be 2 Tanks that will serve as the clarifiers; and activated sludge will be pumped back to the buffer tank, creating a closed loop system.
- Settled sludge from the clarifier mainly consists of scoured bacteria that is returned to the anaerobic buffer tank which seeds the anaerobic digester.
- The RAS process improves the nitrification, stabilizes the primary sludge and ensures the sludge will always stay active, even during periods of low flow.
- Hydraulic retention: 0.6 Days

### **Disinfection Contact tank. (New Tank)**

- There will be a Chlorine contact tank used for chlorine dosing.
- This tank will be discharged by the existing discharge pump and pipeline.



## SECTION 6. SIMILAR INSTALLATIONS



## SECTION 7. MAINTENANCE REQUIREMENTS.

### *Daily Maintenance*

- Should there be any inorganic build-up in the in-line screen it should be removed and disposed of in the appropriate manner, in-line with hazardous waste disposal legislation.
- Check that all mechanical Equipment is operational

### *Weekly Maintenance*

- Check that all mechanical Equipment is operational.
- Check the timers to ensure that the timing has not changed due to electrical failure.
- Remove all non-organic material from septic tank.
- Open sludge drains valves to feed the Anaerobic tank.
- Add bacteria as per recommended dosage.

### *Monthly Maintenance*

- **Sampling** – take feed sample and final treated effluent sample for SANAS accredited lab analysis.
- **Manual Screen** - Remove all non-organic material & agitate the accumulated organic material.
- **Bioreactor pumps** – Verify that pumps are clear of obstruction and grease mechanical components where required.
- **Clarifier Pumps** - Verify that the submersible pumps are clear of obstructions and in good running order.
- **Chlorine Equipment** - Measure & top up chlorine to design specifications
- **Electrical** - Check timers are set to correct intervals and test & ensure time is accurate.
- *Take water sample and submit to laboratory for analysis.*



## SECTION 8. OPERATING COSTS

| Monthly Operating Cost |   |              |
|------------------------|---|--------------|
| ITEM                   | Description   | Monthly Rate |
| 1                      | Provision for replacement of critical equipment     | R 1 000.00   |
| 2                      | Monthly Maintenance (Labour, travelling & Vehicles) | R 2 500.00   |
| 3                      | Monthly Maintenance (Plant Consumables)             | R 3 890.00   |
| 4                      | Monthly Maintenance (Lab Analysis & Reports)        | R 3 000.00   |
| Total Excl. Vat        |   | R 10 390.00  |

## SECTION 9. ELECTRICAL REQUIREMENTS & FOOTPRINT.

- Existing power supply is required.
- Timers on Bioreactor & Disinfectant Pumps (24 hours with 15-minute interval settings)
- Earthing, lighting protection and earth matting has been excluded
- Feed cable provision and installation excluded
- If the plant is connected to a standby generator, we recommend that a soft Starter be installed in the control panel. This can be offered at an additional rate.
- With regards to the plant footprint, the new plant will fit into the available space.

## SECTION 10. INSTALLATION.

- **FLUIDCO** will provide the following personnel for site installation and supervision:
  - 1 x Site Supervisor
  - 1 x Senior Technician
  - Unskilled labour as required
- There will always be at least 2 x representatives on site, the project engineer and project supervisor will conduct site visits during the installation.
- Price will include the following
  - All transport to and from site
  - All components,
  - All labour costs,
  - Start up chemicals,
  - Training and Handover,
  - Removal of old plant from site – this can be excluded as a cost saving if preferred,



## SECTION 11. DELIVERY & OFFLOADING

- Plant to be delivered to site
  - **FLUIDCO** will offload the plant and equipment

## SECTION 12. HSEQ REQUIREMENTS.

- All PPE Included in proposal.
- No provision for a safety file is allowed for.
- Working at heights, excavation permits, and all other site-specific requirements is excluded
- All Contractors packs and the approval thereof and related labour and traveling cost are Excluded

## SECTION 13. CUSTOMER RESPONSIBILITIES.

- Provision of suitable access for delivery and installation of plant.
- Secured Storage on site
- Safe access for all approved **FLUIDCOL** employees and contractors to the job site
- Piping, equipment or electrical to and from the defined battery limits (extraction and discharge lines)
- Security and Fire Protection systems as per local regulations
- Electrical supply from a mains breaker, with connection to our plant distribution board
- A representative to help coordinate activities that require support from the customer
- Environmental and discharge permits
- First fill of systems - we will require 100KL of clean water to fill tanks at startup.

## SECTION 14. GUARANTEES.

- **Mechanical Guarantee:** All Mechanical & Electronic Equipment carries a 12-month OEM guarantee
- **Structural Guarantee:** A Structural guarantee of 8 years is offered on tanks, subject to correct upkeep.
- **Process Guarantee:** Final Effluent is guaranteed to be in line with DWS's General Standards requirements, subject to **FLUIDCO** conducting the maintenance of the plant.
- **Start-up and commissioning:** The plant will take between 2 – 8 weeks to reach the desired final effluent qualities
- **FLUIDCO**'s liability to the client shall in any event and under all circumstances be limited to the costs of remedying any defective workmanship, repairing any defective goods or replacing any defective goods not capable of repair.
- **FLUIDCO** shall under no circumstances whatsoever be liable for any loss of profit or any damages of whatsoever nature, direct or indirect, consequential or otherwise, suffered by the client or any other person or entity, whether or not caused by the negligence of **FLUIDCO**, its agents or employees.
- The Warranty is subject to the client's compliance to service procedures and maintaining the supplied equipment as prescribed and in accordance with **FLUIDCO**'s specifications and instructions. A separate maintenance service agreement may be negotiated separately based on further discussion.



## SECTION 15. INCLUSIONS TO THE OFFER.

- Complete design, manufacturing, testing and installation of biological WWTP.
- Delivery
- All Mechanical Equipment other than specified
- Installation
- Living out allowance for technical team
- Commissioning of plant onsite
- Operations manual with guarantee letter.

## SECTION 16. EXCLUSIONS TO THE OFFER.

- Excavations, intermediate and hard rock excavations, groundwork and subsoil drainage
- Site Lighting, Earthing and earth matting, Lightning Protection, PLC Connection & telemetry
- Engineering drawings
- Pipe reticulation from plant for final water
- No allowance was made for retention or performance bonds.
- Any delays on site will be charged at R15 750.00 per day, excluding all lodging & traveling which will be billed at cost plus 15%.

## SECTION 17. GENERAL TERMS & CONDITIONS.

- Full terms and conditions apply and may be obtained on request.
- All prices are excluding vat; prices will remain firm for a period of 30 days.
- This design and proposal are the intellectual property of **FLUIDCO**, this information cannot be used for tender purposes or basis for obtaining quotations without the written consent of **FLUIDCO**.
- **FLUIDCO** reserves the right to change technical aspects, designs, flow patterns, flow rates and equipment without prior notice to the client to ensure better performance and efficiency.
- Pricing submitted in this proposal are estimates only and will be confirmed after site visit and a clear understanding of your requirements by our engineering and design team

## SECTION 18. LEAD TIMES.

- |                                    |                   |
|------------------------------------|-------------------|
| ○ Procurement of materials         | : 4-6 Weeks       |
| ○ Workshop Fabrication and fitment | : 1 - 2 Weeks     |
| ○ Delivery                         | : 5 Days          |
| ○ Installation                     | : 15 Working Days |



## SECTION 19. PAYMENT TERMS.

- 60% On proposal acceptance
- 30% upon commencement of installation
- 10% upon commissioning and handover
- All payments are strictly 7 Days from invoice.
- Prices are nett, current and firm for 30 days.
- Prices are in ZAR at current exchange rates.



## SECTION 20. COST PROPOSAL

| Code                     | Description   | Total list   |
|--------------------------|---|--------------|
| V10000XXH                | Vertical Chemical tank HD 10000 litre   | R 3 060.00   |
| V2200XH                  | Vertical Chemical Tank HD 2200 litre  | R 178.50     |
| ST8 4EVR                 | Rubber Tank Seal - 110mm  | R 5 380.25   |
| ST7 4EVR                 | Rubber Tank Seal - 50mm   | R 6 648.23   |
| PL Rosette 100mm<br>Glof | Plastic rosette media - 100mm   | R 514 080.00 |
| DE22                     | InverEco pool pump, 1kW, 220V   | R 12 416.59  |
| SR7mm                    | Ski Rope 7mm per m.   | R 471 750.00 |
| T.A.L. 3 Core 2.5        | 3 Core Cable 100m x 2.5mm   | R 2 113.95   |
| 040/00110                | 90° Elbow SW  | R 7 356.24   |
| 046/0110                 | Tee SW  | R 630.21     |
| AGRICO110/12             | 110mm Upvc Class 12   | R 26 775.00  |
| 037/0110                 | PVC Flange Adaptor 110mm  | R 6 136.07   |
| AGRICO50/12              | 50mm Upvc Class 12  | R 3 761.25   |
| 040/0050                 | 90° Elbow SW 50mm   | R 875.93     |
| 046/0050                 | Tee SW 50mm   | R 783.87     |
| 048/0050x0040x0040       | Adaptor Male SW 50mm  | R 290.70     |
| 044/0050                 | 50mm Pipe Clip  | R 462.06     |
| 043/0050x0040            | 50mm *1 1/2" Female Adaptor   | R 404.94     |
| 017/0050                 | PVC Equal Cross 50mm  | R 475.32     |
| 604/0050                 | Ball Valve S/U SW 50mm  | R 2 515.32   |
| 054/0050x0040            | 50mm Black Tank Connector Heavy Duty  | R 1 070.49   |
| AGRICO50/12              | 50mm Upvc Class 12  | R 8 274.75   |
| 040/0050                 | 90° Elbow SW 50mm   | R 875.93     |
| 046/0050                 | Tee SW 50mm   | R 1 567.74   |
| 017/0050                 | PVC Equal Cross 50mm  | R 950.64     |
| 036/0050*0032            | PVC Tee Reducing  | R 288.66     |
| 043/0032*0025            | Adaptor Female SW   | R 98.94      |
| DIFF-250                 | 25cm Rubber Diffuser  | R 24 862.50  |
| GHBH 003 34 2R4          | Air blower, side channel (regenerative), 2.2 kW double-stage, 380 Volt, 3ph, three-phase, 150 m3/h max. air flow, -330 mbar max. vacuum, 440 mbar max. pressure | R 61 337.70  |
| B Stone 5lph DOS<br>Pump | Blackstone 5 L/h Chemical Dosing Pump   | R 40 443.00  |
| V500XXH - RT             | Vertical Chemical Extra Heavy Duty Tank   | R 10 608.00  |
| LS50                     | Lamella Block   | R 38 148.00  |
| C Panel Mods             | Control panel modifications - existing  | R 38 250.00  |
| RTU1026                  | BioZyme Sewer Gobbler 1E8 Liquid  | R 6 107.25   |



|  |                                |                       |
|--|--------------------------------|-----------------------|
| S. Hypo12-15%                              | BioZyme Sodium Hypochlorite    | R 2 550.00            |
|  | Consumables                    | R 25 500.00           |
| Sub-Total Componentry                      |                                | R 1 327 028.01        |
| 5% Contingencies                           |                                | R 66 351.40           |
| <b>Total Componentry</b>                   |                                | <b>R 1 393 379.41</b> |
| Labour - unskilled/hr                      | Labour - remove existing plant | R 24 097.50           |
| Labour - Skilled/hr                        | Labour - remove existing plant | R 14 917.50           |
| Director/hr                                | Labour                         | R 68 850.00           |
| Labour - unskilled/hr                      | Labour - install new plant     | R 24 097.50           |
| Labour - Skilled/hr                        | Labour -install new plant      | R 14 917.50           |
| Director/hr                                | Labour                         | R 68 850.00           |
| Transport                                  | Transport of plant             | R 31 875.00           |
| <b>Total Labour, Management and Travel</b> |                                | <b>R 247 605.00</b>   |
| <b>Total Componentry and Installation</b>  |                                | <b>R 1 640 984.41</b> |
| <b>10% Discount</b>                        |                                | <b>R 164 098.44</b>   |
| <b>Total Revised Price after Discount</b>  |                                | <b>R 1 476 885.97</b> |

Prices are nett, current, and exclude VAT. The discount is applicable if the proposal is accepted within 30 days of submission.

We trust that our proposal meets with your approval. Should you require more information, please do not hesitate to contact us.

Yours Sincerely,

**Kevi Levin.**